



File Information			Discharge Summary						
File name	ABRAMSD5_20190828-113550.ft		Start time	8/28/2019 11:25:50 AM	End time	8/28/2019 11:33:12 AM			
Start date and time	8/28/2019 11:24 AM		# Stations	8	Avg interval	40			
Calculations engine	FlowTracker2		Mean depth	0.370 ft					
Data collection mode	Discharge		Mean velocity	1.1217 ft/s	Total width	2.100 ft			
			Mean SNR	48 dB	Total area	0.7770 ft ²			
			Mean temp	43.819 °F	Total discharge	0.8716 ft ³ /s			
System Information			Site Details						
Sensor type	Top Setting		Site name	ABRAMSD5					
Handheld serial number	FT2H1747037		Site number	003					
Probe serial number	FT2P1747048		Operator(s)	Jack Landers					
Probe firmware	1.23		Comment	Abrams Creek Gage					
Handheld software	1.4								
Discharge Uncertainty			Discharge Settings			Station Warning Settings			
Category	ISO	IVE	Discharge equation	Mid Section			Station discharge caution	5.00	%
Accuracy	1.0%	1.0%	Discharge uncertainty	IVE			Station discharge warning	10.00	%
Depth	0.7%	9.8%	Discharge reference	Rated			Maximum depth change	50.00	%
Velocity	1.5%	18.1%					Maximum spacing change	100.00	%
Width	0.2%	0.2%							
Method	3.6%								
# Stations	6.6%								
Overall	7.8%	20.6%							
Summary overview			Data Collection Settings			Quality Control Settings			
No changes were made to this file			Salinity	0.000	PSS-78	SNR threshold	10	dB	
Quality control warnings			Temperature		°F	Standard error threshold	0.0328	ft/s	
			Sound speed		ft/s	Spike threshold	10.00	%	
			Mounting correction	0.00	%	Maximum velocity angle	20.0	deg	
						Maximum tilt angle	5.0	deg	


Discharge chart



Velocity chart







Depth chart



Measurement results														
St#	Time	Location (ft)	Method	Depth (ft)	%Depth	Measured Depth (ft)	Samples	Velocity (ft/s)	Correction	Mean Velocity (ft/s)	Area (ft ²)	Flow (ft ³ /s)	%Q	
0	11:25 AM	2.800	None	0.000	0.0000	0.000	0	0.0000	1.0000	0.0055	0.0000	0.0000	0.00	✓
1	11:26 AM	3.100	0.6	0.290	0.6000	0.174	80	0.0055	1.0000	0.0055	0.0870	0.0005	0.05	✓
2	11:27 AM	3.400	0.6	0.310	0.6000	0.186	80	1.1749	1.0000	1.1749	0.0930	0.1093	12.54	✓
3	11:28 AM	3.700	0.6	0.390	0.6000	0.234	80	0.6302	1.0000	0.6302	0.1170	0.0737	8.46	✓
4	11:29 AM	4.000	0.6	0.550	0.6000	0.330	80	1.1688	1.0000	1.1688	0.1650	0.1929	22.13	✓
5	11:31 AM	4.300	0.6	0.550	0.6000	0.330	80	1.4878	1.0000	1.4878	0.1650	0.2455	28.16	✓
6	11:32 AM	4.600	0.6	0.500	0.6000	0.300	80	1.6652	1.0000	1.6652	0.1500	0.2498	28.66	✓
7	11:33 AM	4.900	None	0.000	0.0000	0.000	0	0.0000	1.0000	1.6652	0.0000	0.0000	0.00	✓

Quality control warnings							
St#	Time	Location (ft)	Method	Depth (ft)	%Depth	Measure d Depth (ft)	Warnings
1	11:26 AM	3.100	0.6	0.290	0.6000	0.174	Boundary Interference,High % Spikes
2	11:27 AM	3.400	0.6	0.310	0.6000	0.186	Standard Error > QC,High Stn % Discharge
3	11:28 AM	3.700	0.6	0.390	0.6000	0.234	Standard Error > QC
4	11:29 AM	4.000	0.6	0.550	0.6000	0.330	Standard Error > QC,High Stn % Discharge
5	11:31 AM	4.300	0.6	0.550	0.6000	0.330	Standard Error > QC,High Stn % Discharge
6	11:32 AM	4.600	0.6	0.500	0.6000	0.300	Standard Error > QC,High Stn % Discharge

Automated beam check Start time 8/28/2019 11:25:28 AM



Automated beam check Quality control warnings

No quality control warnings