

Advanced Validation Methods & Technical Assistance: Supply Meter Testing



What is a Meter Test?

- *In-situ*
- *Volumetric comparison*
- *Using a known volume*





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources




Meter Test Misconceptions

- *“Got a certificate”*
- *“We have redundant meters”*
- *“Guaranteed it would be accurate”*
- *“Only needs calibration”*





Meter Calibration



1. As Found

Max Error: -0.46 % of reading

Nominal Input [iwc]	Actual Input [iwc]	Nominal Output [mA]	Actual Output [mA]	Found Error [% of reading]
2.04	2.05	5.60	5.5776	-0.4647
12.75	12.76	8.00	7.9748	-0.3260
51.02	51.04	12.00	11.9782	-0.1963
114.79	114.80	16.00	15.9923	-0.0516
204.07	204.06	20.00	20.0107	0.0555
114.79	114.80	16.00	15.9928	-0.0485
51.02	51.00	12.00	11.9779	-0.1728
12.75	12.76	8.00	7.9803	-0.2572
2.04	2.06	5.60	5.5902	-0.3094

PASSED

2. As Left

Max Error: 0.42 % of reading

Nominal Input [iwc]	Actual Input [iwc]	Nominal Output [mA]	Actual Output [mA]	Found Error [% of reading]
2.04	2.08	5.60	5.6288	0.2398
12.75	12.72	8.00	8.0016	0.0875
51.02	51.03	12.00	11.9905	-0.0873
114.79	114.77	16.00	15.9988	-0.0012
204.07	204.04	20.00	20.0158	0.0849
114.79	114.78	16.00	16.0002	0.0043
51.02	51.03	12.00	11.9908	-0.0848
12.75	12.76	8.00	8.0015	0.0077
2.04	2.05	5.60	5.6270	0.4168

PASSED








Primary and Secondary Devices



Measurement Element



Secondary Electronics*



SCADA System

*Calibration



COLORADO

Colorado Water
Conservation Board

Department of Natural Resources




Why Perform Meter Tests?

- *Only way to verify performance*
- *Protect your investment*
- *Improve water balance*
- *Improve data validity score*





Why Perform Meter Tests?





How to Test a Meter

- Use a known volume
- Use a meter of known accuracy
- Consider flow conditions and pipe configuration





COLORADO


Colorado Water
Conservation Board

Department of Natural Resources



Testing with a known volume

- *Preferred Method*
- *Use Tank or Clearwell*
- *Measure Level Change*
- *Requires Accurate Gal/Ft*






COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Testing with a known volume





COLORADO

Colorado Water
Conservation Board


Department of Natural Resources



Testing with a known volume

Testing Requirements:

- Tank
- Accurate Measurement or Drawing
- Ability to isolate for extended period
- Way to accurately measure water level





COLORADO
Colorado Water
Conservation Board
Department of Natural Resources






Testing with a Reference Meter





Velocity Profiles

- “Laminar Flow”
- Turbulent Flow
- Fully Developed Flow Profile





COLORADO


Colorado Water
Conservation Board

Department of Natural Resources




Velocity Profiles

Butterfly Valve




Gate Valve






Velocity Profiles


Insufficient Straight Pipe



Pipe build up



Fully Developed





COLORADO


Colorado Water
Conservation Board

Department of Natural Resources



Ultrasonic Meters

- Transit Time Ultrasonic measures time difference of sound pulses between transducers
- Requires Pipe Information
- Does not use velocity profile





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Insertion Meters

- *Electromagnetic or Paddle-Wheel*
- *Single or Multi-Point Measuring*
- *Requires Accurate Velocity Profile*





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Testing with a Reference Meter

Testing Requirements:

- Exposed Pipe – possibly with tap
- Straight Pipe upstream and downstream of reference meter!!





COLORADO


Colorado Water
Conservation Board

Department of Natural Resources



Measurement Uncertainty

- *Inaccurate Tank Dimensions*
- *Unstable Velocity Profile*
- *Instrument Inaccuracy*
- *Inaccurate Piping Information*
- *Etc.*





COLORADO


Colorado Water
Conservation Board

Department of Natural Resources




Measurement Uncertainty

Measurement Certainty



Total Uncertain Volume



$$\text{Uncertain Volume} = (\pi r^2) * (4\delta)$$




COLORADO

Colorado Water
Conservation Board

Department of Natural Resources




Measurement Uncertainty





Measurement Uncertainty



$$\text{Uncertain Volume} = 2 * \text{Register Resolution}$$



COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Measurement Uncertainty

- Inherent Meter Accuracy (+/- 2%)
- Pipe Dimensions
- Velocity Profile Uncertainty






COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Known Volume Test Summary



Pros

- Physical measurement
- Non-invasive
- No additional equipment
- Known Error Margins

Cons

- Reservoir required
- Known geometry
- Accurate level sensing
- Operational interruption

$$Accuracy = \frac{V_m}{V_r}$$



COLORADO

Colorado Water
Conservation Board

Department of Natural Resources




Reference Meter Test Summary

Pros

- Flow profiling
- Verify internal diameter
- No operational interruptions


Cons

- Access to straight length
- Unreliable at low flow rates
- Secondary meter
- Less certain error margins





Meter Test Results





Use of Test Results

	Meter A	Meter B	Meter C
Volume Supplied	100	1,000	10,000
Meter Accuracy	105.5%	112.6%	99.1%

Weighted Average: (Sum of Volume x Accuracy) / (Sum of Volume)

Example: $(100 \times 105.5 + 1,000 \times 112.6 + 10,000 \times 99.1) / (100 + 1,000 + 10,000)$

= 100.37%



Use of Test Results

	Meter A	Meter B	Meter C
Volume Supplied	100	1,000	10,000
Meter Accuracy	105.5%	112.6%	99.1%

Comparison of Calculations

- Weighted Average – Average Accuracy = 100.4%
- Simple Average – Average Accuracy = **105.7%**



Use of Test Results

- *Adjustment to AWWA Audit Software*
- *Recalibrate/Repair Meter*
- *Leave blank if no test results?*

Correct data grading for each input, determine the highest grade where utility meets or exceeds all criteria for that grade and all grades below it.

<----- Enter grading in column 'E' and 'S' ----->

Volume from own sources:	+	?		
Water imported:	+	?		
Water exported:	+	?		

WATER SUPPLIED: 0.000

Billed metered: + ?

Master Meter and Supply Error Adjustments

Pcnt:	Value:
+	?
+	?
+	?

Enter negative % or value for under-registration
Enter positive % or value for over-registration

Click here: ?
for help using option



COLORADO

Colorado Water
Conservation Board


Department of Natural Resources



Use of Test Results

Summary Stats

Total Tests	70
Min	32.2%
Max	133.6%
Mean	100.3%
Median	101.2%





COLORADO



Colorado Water
Conservation Board

Department of Natural Resources



Data Request for Meter Testing

- Meter Make/Model
- Meter Size
- Flow History
- Upstream & Downstream Straight Pipe
- Piping Configuration
- Proximity to Tank/Clearwell
- Previous Test/Calibration Results



Advanced Validation Methods & Technical Assistance: Billing Data Analysis



COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Why perform Consumption Data Analysis


- Confirm consumption volumes
 - Both metered and unmetered
 - Differentiate billed vs. unbilled
- Identify practices that may contribute to water losses
- Identify lost revenue or new sources of revenue
- Analysis and validation can be done from a volume perspective and from a revenue perspective





Why perform Consumption Data Analysis

Meter Reading and Billing System

Volume Recorded



Meter Readings Collected




Data Processed

read.p	read.c
62549	62549
62549	62549
62549	62549

meterID	Meter Multiplier
13576	10
198604	100
B23487	10

Billing, Reporting,
and Archiving




Month	Billings
Jan	\$ 324,568
Feb	\$ 431,243
Mar	\$ 501,387



Why Analyze Billing Data?

Volume Recorded



- ✗ Meter malfunction
- ✗ Inaccurate meters
- ✗ Incorrect meter or customer data

Meter Readings Collected



- ✗ Missed or Incorrect reads
- ✗ Failed data transmission
- ✗ Incomplete data stored

Data Processed

read.p	read.c
62549	62549
62549	62549
62549	62549

meterID	Meter Multiplier
13576	10
198604	100
B23487	10

- ✗ Duplicate records
- ✗ Consumption adjustments
- ✗ Meter rollovers
- ✗ Consumption estimates
- ✗ Re-read

Billing, Reporting, and Archiving




Month	Bill: \$
Jan	24,568
Feb	\$ 431,243
Mar	\$ 501,387

- ✗ Reporting for financial purposes
- ✗ Bill adjustments
- ✗ Archive quirks



Why perform Consumption Data Analysis





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Confirm Consumption Volume






COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Confirm Consumption Volume






COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Confirm Consumption Volume





Basic checks – Volumes

- Relevant to **potable water** audit
 - ✓ Include potable water services
 - ✓ Include potable water uses that may be tracked in a different system – wholesale, hydrant sales, temporary meters, construction meters
 - ✓ Exclude raw, recycled or other types of non-potable water



Basic checks – Volumes


- Relevant to **water audit period**





Basic checks – Volumes

- Relevant to **water audit period**





Basic checks – Volumes

- Relevant to **water audit period**
 - ✓ Lag time analysis

12-month period	Total Consumption (MG)	Difference with Audit Period
Audit Period	25,648	--
Shifted by 1 month	25,635	-0.05%
Shifted by 2 months	25,800	0.60%



Basic checks – Volumes

- Relevant to **water audit period**
 - ✓ Lag time analysis

12-month period	Total Consumption (MG)	Difference with Audit Period
Audit Period	578.9	-
Shifted by 1 month	575.8	- 0.50%
Shifted by 2 months	549.6	- 4.75%



COLORADO


Colorado Water
Conservation Board

Department of Natural Resources



Basic checks – Volumes

- Relevant to **water audit period**
 - ✓ Prorating Consumption





COLORADO


Colorado Water
Conservation Board

Department of Natural Resources



Basic checks – Volumes


- Correct
 - ✓ Duplicates
 - ✓ Negatives
 - Adjustments
 - Meter Changes
 - Meter Rollovers





Basic checks – Volumes

- Correct
 - ✓ Duplicates
 - ✓ Negatives
 - Adjustments
 - Meter Changes
 - Meter Rollovers
 - ✓ Outliers





Basic checks – Volumes

- Correct
 - ✓ Duplicates
 - ✓ Negatives
 - Adjustments
 - Meter Changes
 - Meter Rollovers
 - ✓ Outliers
 - ✓ Units and Multipliers

Comparing Meter Model, Size, and Multiplier				
Size	Model	Multiplier (0.01)	Multiplier (0.1)	Multiplier (1.0)
3/4 Inch	35	3988	-	2
3/4 Inch	70	1	-	-
3/4 Inch	PF-170	1	-	-
3/4 Inch	PF-35	2000	1	-
1 Inch	35	1	-	-
1 Inch	70	6586	-	-
1 Inch	PF-170	1	-	-
1 Inch	PF-70	5325	1	1
1.5 Inch	120	-	371	-
1.5 Inch	PF-120	1	213	-
1.5 Inch	PF-170	-	1	-
2 Inch	170	2	258	-
2 Inch	PF-170	-	120	-
4 Inch Comp	70	-	1	-
6 Inch	170	-	1	-




Other checks – Revenues

- Correct customer and meter data

✓ Customer type

✓ Service type





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources




Other checks – Revenues

- Correct customer and meter data
 - ✓ Customer type
 - ✓ Service type
 - ✓ Meter size
 - Size in field matches size in system
 - Appropriate for consumption volumes
- Account status
 - ✓ Active or Inactive
- Other utility specific regulation
 - ✓ Separate fire suppression system requirement
 - ✓ Irrigation restrictions
 - ✓ Volume adjustment for fire uses



Other checks – Revenues

- Knowing your largest consumers





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



In summary

- Meter reading and billing systems are a invaluable tool for any water utility – not just for it's primary purpose – but also to:
 - ✓ Assure correct volumes are billed and recorded
 - ✓ Track utility processes that may impact water losses and revenue
 - ✓ Complement effective NRW reduction strategies
- These checks can have a significant impact on a water audit which in turn will shape the selection of cost-effective strategies for the reduction of NRW



COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Data Request for Billing Data Analysis

Billing Data Analytics (Integrity Review & Anomaly Flagging)


- Timeframe for the data requested unless noted otherwise: Calendar 2020 plus 2 months on the front and back end (so 16 months total). In order to perform this analysis, we will need to receive raw billing data or meter read data in a specific format. We will need data in a single file in **.csv format** with a **single record for each bill**. Each record should include the following fields (variables), if you have them available.

REQUESTED BILLING DATA FIELDS		
1	Location ID	<i>a unique identifier for a parcel or service connection in the water system, similar to an address</i>
2	Customer ID	<i>a unique identifier for a customer at a given location</i>
3	Meter ID	<i>a unique identifier for a meter at a given location</i>
4	Meter Size	<i>indication of meter size</i>
5	Meter Installation Date	<i>The installation date for the meter body, ideally including meters that have been replaced.</i>
6	Meter Total Lifetime Throughput	<i>The total volume of water that has passed through the meter, accounting for meter rollovers.</i>
7	Service or Account Type	<i>identifying fields that indicate what type of service is provided (e.g., "residential")</i>
8	Read Date	<i>the date on which the meter was read</i>
9	Previous Read Date	<i>the date on which the meter was last read</i>
10	Read Volume	<i>the raw totalizer volume from the meter on the read date</i>
11	Previous Read Volume	<i>the raw totalizer volume from the meter on the previous read date</i>
12	Units	<i>the units that the read volumes are recorded in</i>
13	Billed Consumption	<i>the actual volume the customer was billed for during the billing period</i>
14	Adjustment or Estimate Flags	<i>any flags that indicate the billed consumption was adjusted or estimated during the billing period.</i>

Advanced Validation Methods & Technical Assistance: Customer Meter Test Design And Results Analysis




Types of Apparent Losses



Unauthorized Consumption




Theft!



Metering Inaccuracy




Customer meter under
registration



read.p	read.r
62549	62549
62549	62549
62549	62549

Data Handling Errors



Reporting or other
clerical errors during the
handling of meter
reading data



Apparent Loss: Customer meter testing



Many meters, **small** volumes





Few meters, **large** volumes




Estimating Customer Metering Inaccuracy

Meter Population



Sample





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Customer Meter Testing Process

1

Design Testing Strategy

Determine goals of testing program and agree upon a sampling strategy and number of meters to sample.

2

Meter Sample Selection

Evaluate meter inventory or billing data to generate a list of meters and alternates based on the agreed test design.

3

Retrieve & Replace Meters

Pull and test small meters identified in meter sample.

4

Meters Tested

Meter testing contractor tests meters and documents results thoroughly (tabular electronic format is preferred).

4

Results Analyzed


Provide meter test results for analysis.



Small Meter Testing Strategy

How many small customer meters do you need to test?

1. Evaluate the level of certainty required to meet management objective.
2. Select a sample size that provides the required level of certainty.






Small Meter Testing Strategy

How many small customer meters do you need to test?

1. It depends.....






COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



95% Confidence Limits for Various Sample Sizes





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Small Customer Meter Sample Design

1

Design Meter Test Sample

- Representative and random meter sample
- What sample size is big enough?



*remember our goal is to appreciate the accuracy of the **whole population***



Small Customer Meter Testing

2

Test Meters

- Careful with meter transport
- Test at low, medium, and high flows
- Document thoroughly
 - include reference volume, testing flow rate, meter totalizer reads, all meter information
 - compile data in analysis-friendly format





Weighting Factors

Time-Based (AWWA M36 4th Edition)

Customer meters spend 15% of the **time** at low flows, 70% at medium flows, and 15% at high flows—need to convert to volume-based weights.

Test Flow Rate (gpm)	Percent of Time Spent at Each Flow Rate	Volume Recorded in 1 Hour at Each Flow Rate (gal)	Percent of Total Volume Recorded at Each Flow Rate
0.5	15%	4.5	1.3%
3	70%	126	35.4%
25	15%	225	63.3%

Volume-Based (AWWA M6)

Customer meters see 15% of the **volume** at low flows, 70% at medium flows, and 15% at high flows—no conversion needed.

2016 Residential End Use Study Weighting (pending publication)

The most recent research on the percent of volume recorded at various flow rates suggests that about 13% of the **volume** is recorded at low flow rates, 55% at medium rates, and 32% at high flow rates—no conversion needed.



COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Weighting Factors

How do weighting factors overall accuracy?

Overall inaccuracy may be inappropriately biased by low flow inaccuracy when using simple mean

Weighting Method	All Results (2011-18) 3,873 records
M36 Weighted Mean	98.36%
M6 Weighted Mean	97.43%
2016 REU Weighted Mean	97.59%
None (simple mean)	96.67%



COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Small Customer Meter Analysis

3

Analyze & Apply Test Results

- Organize all test results
- Analyze accuracy findings
- Consider confidence limits
- Calculate Apparent Loss Volumes





Small Customer Meter Analysis

3

Analyze & Apply Test Results

Accuracy Results Analysis Considerations


- Averaging across flow rate results
 - time-weighting
 - volume-weighting and consumption profiling
- Handling stuck meters





Small Meters (2018) – Flagged vs. Random


3/4" and 1" Results (2018)



WSO determined to a 95% confidence level that the mean accuracy for the random sample meters is somewhere **between 0.7% and 2.0% higher** than the flagged meters in the case of 3/4" and 1" meters.



Accuracy and Age





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Small Customer Meter Testing

Meter Size	Meter Population	Registered Consumption Volume (MG)	Volume-Weighted Average Accuracy	Unregistered Consumption Volume (MG)
5/8"	13,548	2,225	92.0%	194
3/4"	1,392	203	98.5%	3
1"	2,145	274	96.9%	9
1-1/2"	311	57	94.0%	4
2"	391	78	97.6%	2

$$\text{Accuracy} = \frac{\text{Registered Consumption Volume}}{\text{Total Registered Volume}}$$

the more consumption, the more important accuracy!



COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Large Customer Meter Testing

- Fewer, more important meters!
- Individual assessment
- Prioritize by consumption
- Flow profiling is key



1

Design Meter Test
Sample

2

Test Meters


3

Analyze & Apply
Results



Large Customer Meter Testing

- 1 Design Meter Test Sample
- Critical for revenue monitoring and recovery
 - Significant factor in apparent loss assessment





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources




Balancing the costs of testing a large customer meter

Cost of Inaccuracy:

- Reduced Volume Recorded
- Retail Value of Water Sold
- Inaccurate water loss estimates

Cost of Testing and Repair:


- Expected Cost of Test and Repair





Overall Schedule

Optimum Testing Frequency for Top Revenue Meters



Testing Frequency	Count of Meters
1 year	1
2 years	10
3 years	11
Regular Testing	36
Total	58



Customer Meter Profiling

Flow Sensor
*Meter-Master
Model 50*

Data Logger
Primelog 2i





**Flow sensor's
magnetic pad
strapped to
meter body**

Meter register



Customer Meter Profiling





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Customer Meter Accuracy Test

- Small and Large meters should have different testing strategies
 - Small meter test samples based on random sampling
 - Large meter test samples based on consumption volume (& revenue generation)
- Meters should be tested at low, medium, and high flow and test results weighted for averaging
- Add layer of consumption volume to calculate Apparent Losses due to meter inaccuracy
- Data request is at a minimum an inventory of customer meters – including age and throughput
 - Additional data may be requested depending on testing objectives

Advanced Validation Methods & Technical Assistance: Real Loss Component Analysis




COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Methods: AWWA Water Balance





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Real Losses



- Leaks from the water mains, valves, hydrants, service lines
- Leaks and overflows from water tanks



COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Why Component Analysis?

**Different types of leakage
should be addressed...
Differently!**





From Water Audit To Component Analysis

1 AWWA Audit Model

AWWA Free Water Audit Software: Reporting Worksheet

Water Audit Report for: CC Please enter system details and contact information on the instructions tab

Reporting Year: 2013

Please enter data in the white cells below. Where available, metered values should be used; if metered values are unavailable please estimate a value. Indicate your confidence in the accuracy of the input data by grading each component (0-5) using the drop-down list to the left of the input cell. Hover the mouse over the cell to obtain a description of the grades.

All volumes to be entered are: MILLION GALLONS (MG) PER YEAR

To select the correct data grading for each input, determine the highest grade where the utility meets or exceeds all criteria for that grade and all grades below it.

Master Meter and Supply Error Adjustments

WATER SUPPLIED

Volume from own sources: 1,300.000 MG/Yr

Water imported: 0.000 MG/Yr

Water exported: 0.000 MG/Yr

WATER SUPPLIED: 1,300.000 MG/Yr

AUTHORIZED CONSUMPTION

Billed unmetered: 85.000 MG/Yr

Billed unmetered: 0.000 MG/Yr

Unbilled unmetered: 0.000 MG/Yr

Unbilled unmetered: 12.750 MG/Yr

Default option selected for unbilled unmetered - a grading of 5 is applied but not displayed

AUTHORIZED CONSUMPTION: 862.750 MG/Yr

WATER LOSSES (Water Supplied - Authorized Consumption)

Apparent Losses

Unauthorized consumption: 2.551 MG/Yr

Default option selected for unauthorized consumption - a grading of 5 is applied but not displayed

Customer metering inaccuracies: 35.417 MG/Yr

Systematic data handling errors: 2.525 MG/Yr

Default option selected for systematic data handling errors - a grading of 5 is applied but not displayed

Apparent Losses: 40.493 MG/Yr

Real Losses (Current Annual Real Losses or CARL)

Real Losses = Water Losses - Apparent Losses: 117.560 MG/Yr

WATER LOSS %: 157.453

NON-REVENUE WATER

NON-REVENUE WATER: 176.408 MG/Yr

Water Losses = Unbilled Metered + Unbilled Unmetered

Total
Real
Losses

2 Component Analysis Model

WaterRF 4372: Real Loss Component Analysis: A Tool for Economic Water Loss Control

Water Audit: City of Centex, CA, USA, 2013

REAL LOSSES COMPONENT ANALYSIS

SUMMARY: REAL LOSS COMPONENT ANALYSIS

System Component	Background Leakage (Acre-feet)	Reported Failures (Acre-feet)	Unreported Failures (Acre-feet)	Total (Acre-feet)
Reservoirs	-	-	-	-
Mains and Appurtenances	-	-	-	-
Service Connections	-	-	-	-
Total Annual Real Loss	-	-	-	-
Real Losses as Calculated by Water Audit	-	-	-	-
Assess/Reported Leakage Currently Running Undetected	-	-	-	-

Note: To the left you have the summary table of the real loss component analysis. Please enter the data in step 1 through 4 for the summary table to be populated.

Step 1: BACKGROUND LEAKAGE, REPORTED LEAKAGE AND UNREPORTED LEAKAGE FROM RESERVOIRS

Instructions: First enter the capacity of all distribution system reservoirs and tanks in use during the audit period. In case the system input volume is based on raw water meters located upstream of the Water Treatment Plant (WTP) then also include the capacity of the WTP reservoir. Next select a reservoir background leakage rate - either the default value provided by the model or a utility specific flow rate. If reservoirs and tanks are well maintained and the utility does not suspect any background leakage from the reservoirs and tanks then enter zero as the utility specific flow rate. In case a reservoir or tank was reported leaking or has overflowed, enter the estimated volume in cell G27. If a proactive investigation/inspection of the system reservoirs and tanks has discovered a leaking reservoir or tank then enter the estimated annual volume lost in cell G28.

Capacity (MG)	Background Leakage Rate (gpm/MG)	Annual Volume (Acre-feet)
0.25	0.25	0.00

Reported Reservoir Leakage and any recorded Reservoir and Tank Overflows

Unreported Reservoir Leakage

Background Leakage, Reported and Unreported leakage from Reservoirs

SYSTEM INPUT VOLUME REPORTED IN ACRE- FEET, BACKGROUND LEAKAGE THEREFORE SHOWN IN ACRE- FEET

Step 2: BACKGROUND LEAKAGE ON MAINS AND SERVICES


Instructions: The background leakage volume from mains and service connections will be automatically calculated after selecting one of the default Infrastructure Condition Factors (ICF) based on infrastructure age or enter a utility specific ICF has been selected and entered in cell P43. The level of background leakage needs to increase with infrastructure age and is higher for systems with higher pressures. The volume of background losses is generally a significant component of the total real loss volume, at times up to 50% of the total volume of real losses. Overestimating ICF used in model is too high to underestimating ICF used in model is too low the background leakage volume might lead to a real loss control strategy that is not truly optimized. Selecting the ICF based on general age of the distribution network should only be seen as a starting point. It is strongly recommended that over time a utility specific ICF is assessed and confirmed through field tests using one of the recommended approaches outlined in the AWWA M36 manual.

System Component	Units	Quantity	Component ICF (gpm/100ft)	Infrastructure Condition Factor	Average Pressure (psi)	Pressure Corrected Calculation	NI Leakage Annual Volume (Acre-feet)

Select Infrastructure Condition Factor (ICF) based on age of distribution network

ICF 1 for System Age < 50 years

ICF 2 for System Age > 50 years





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Types of Real Losses

Surfaced Leak



Background Leakage



Unreported and undetectable using traditional acoustic equipment

Unreported Leakage



Unreported and able to be detected using traditional acoustic equipment

Reported Leakage



Surfaced and reported by public or utility staff




COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Types of Real Losses






COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Recoverability of Real Losses



The AWWA audit software will model the **technical minimum** level of real loss based on system infrastructure data.

- Current Annual Real Losses
- - - Economic Level of Real Losses
- Unavoidable Annual Real Losses



AWWA Technical Minimum Leakage

Excel formula bar showing the formula for cell I17:

$$=IF(ISBLANK(Instructions!\$D\$34),"",IF(Instructions!\$D\$34="Megalitres (thousand cubic metres)",IF(AND('Reporting Worksheet'!G69>=25,'Reporting Worksheet'!G62*20+'Reporting Worksheet'!G63>3000),(((18*'Reporting Worksheet'!G62)+(0.8*'Reporting Worksheet'!G63)+(25*('Reporting Worksheet'!G63*'Reporting Worksheet'!R68/1000)))*'Reporting Worksheet'!G69/1000000)*365,"Not Valid"),IF(AND('Reporting Worksheet'!G69>=35,'Reporting Worksheet'!G62*32+'Reporting Worksheet'!G63>3000),(((5.41*'Reporting Worksheet'!G62)+(0.15*'Reporting Worksheet'!G63)+(7.5*('Reporting Worksheet'!G63*'Reporting Worksheet'!R68/5280)))*'Reporting Worksheet'!G69)/IF(Instructions!\$D\$34="Million gallons (US)",1000000,325851.427242)*365,"See limits in definition"))))$$

AWWA Pipe Water Audit Software: WAS v5.0

System Attributes and Performance Indicators

Water Audit Report for: **Water District**
Reporting Year: **2019-2020** | **7/2019 - 6/2020**

*** YOUR WATER AUDIT DATA VALIDITY SCORE IS: 63 out of 100 ***

System Attributes:

Apparent Losses:	79.168	acre-ft/yr
+		
Real Losses:	435.255	acre-ft/yr
=		
Water Losses:	514.423	acre-ft/yr
Unavoidable Annual Real Losses (UARL):	191.00	acre-ft/yr
Annual cost of Apparent Losses:	\$108,863	
Annual cost of Real Losses:	\$230,550	

Valued at **Variable Production Cost**
Return to Reporting Worksheet to change this assumption



From Water Audit To Component Analysis

1 AWWA Audit Model

AWWA Free Water Audit Software: Reporting Worksheet

Water Audit Report for: CC Please enter system details and contact information on the instructions tab

Reporting Year: 2013

Please enter data in the white cells below. Where available, metered values should be used; if metered values are unavailable please estimate a value. Indicate your confidence in the accuracy of the input data by grading each component (0 to 5) using the drop-down list to the left of the input cell. Hover the mouse over the cell to obtain a description of the grades.

All volumes to be entered are: MILLION GALLONS (MG) PER YEAR

To select the correct data grading for each input, determine the highest grade where the utility meets or exceeds all criteria for that grade and all grades below it.

Master Meter and Supply Error Adjustments

WATER SUPPLIED

Volume from own sources: 1.360 MG/Y

Water imported: 0.00 MG/Y

Water exported: 0.00 MG/Y

WATER SUPPLIED: 1.360 MG/Y

Enter grading in column 'C' and 'J'

Port: 2.00% Value: 0.00 MG/Y

Authorized Consumption

Billed unmetered: 0.00 MG/Y

Billed unmetered: 0.00 MG/Y

Unbilled unmetered: 0.00 MG/Y

Unbilled unmetered: 0.00 MG/Y

Default option selected for unbilled unmetered - a grading of 5 is applied but not displayed

AUTHORIZED CONSUMPTION: 0.00 MG/Y

WATER LOSSES (Water Supplied - Authorized Consumption)

1.360 MG/Y

Apparent Losses

Unauthorized consumption: 0.00 MG/Y

Default option selected for unauthorized consumption - a grading of 5 is applied but not displayed

Customer metering inaccuracies: 0.00 MG/Y

Systematic data handling errors: 0.00 MG/Y

Default option selected for systematic data handling errors - a grading of 5 is applied but not displayed

Apparent Losses: 0.00 MG/Y

Real Losses (Current Annual Real Losses or CARL)

Real Losses = Water Losses - Apparent Losses: 0.00 MG/Y

WATER LOSS %: 0.00%

NON-REVENUE WATER

NON-REVENUE WATER: 0.00 MG/Y

Water Losses - Unbilled Metered - Unbilled Unmetered

Total
Real
Losses

2 Component Analysis Model

WaterRF 4372: Real Loss Component Analysis: A Tool for Economic Water Loss Control

Water Audit: City of Centex, CA, USA, 2013

REAL LOSSES COMPONENT ANALYSIS

SUMMARY: REAL LOSS COMPONENT ANALYSIS

System Component	Background Leakage (Acre-feet)	Reported Failures (Acre-feet)	Unreported Failures (Acre-feet)	Total (Acre-feet)
Reservoirs	0.00	0.00	0.00	0.00
Mains and Appurtenances	0.00	0.00	0.00	0.00
Service Connections	0.00	0.00	0.00	0.00
Total Annual Real Losses	0.00	0.00	0.00	0.00
Real Losses as Calculated by Water Audit	0.00	0.00	0.00	0.00
Assess/Reported Leakage Currently Running Undetected	0.00	0.00	0.00	0.00

Note: To the left you have the summary table of the real loss component analysis. Please enter the data in step 1 through 4 for the summary table to be populated.

Step 1: BACKGROUND LEAKAGE, REPORTED LEAKAGE AND UNREPORTED LEAKAGE FROM RESERVOIRS

Instructions: First enter the capacity of all distribution system reservoirs and tanks in use during the audit period. In case the system input volume is based on raw water meters located upstream of the Water Treatment Plant (WTP) then also include the capacity of the WTP reservoir. Next select a reservoir background leakage rate - either the default value provided by the model or a utility specific flow rate. If reservoirs and tanks are well maintained and the utility does not suspect any background leakage from the reservoirs and tanks then enter zero as the utility specific flow rate. In case a reservoir or tank was reported leaking or has overflowed, enter the estimated volume in cell G27. If a proactive investigation/inspection of the system reservoirs and tanks has discovered a leaking reservoir or tank then enter the estimated annual volume lost in cell G28.

Capacity (MG)	Background Leakage Rate (gpm/MG)	Annual Volume (Acre-feet)
0.00	0.00	0.00

Select Reservoir Background Leakage Rate

Default Value: 0.00 gpm/MG

Utility Specific: 0.00 gpm/MG

Background Leakage Rate: 0.00 gpm/MG


Step 2: BACKGROUND LEAKAGE ON MAINS AND SERVICES

Instructions: The background leakage volume from mains and service connections will be automatically calculated after selecting one of the default Infrastructure Condition Factors (ICF) based on infrastructure age or enter a utility specific ICF. The level of background leakage needs to increase with infrastructure age and is higher for systems with higher pressures. The volume of background losses is generally a significant component of the total real loss volume, at times up to 50% of the total volume of real losses. Overestimating ICF used in model is too high to underestimate ICF used in model is too low the background leakage volume might lead to a real loss control strategy that is not truly optimized. Selecting the ICF based on general age of the distribution network should only be seen as a starting point. It is strongly recommended that over time a utility specific ICF is assessed and confirmed through field tests using one of the recommended approaches outlined in the AWWA M20 manual.

System Component	Units	Quantity	Component ICF (gpm/100ft)	Infrastructure Condition Factor	Average Pressure (psi)	Pressure Corrected Calculation	Background Leakage (Acre-feet)	Annual Volume (Acre-feet)

Select Infrastructure Condition Factor (ICF) based on age of distribution network


ICF 1 for System Age < 50 years: 10





Component Analysis Model - WRF 4372

- **Background**
 - Modeled from Infrastructure Data
- **Reported Failures**
 - Leaks called in by customers or utility staff
 - Noticeable without leak equipment
- **Unreported Failures**
 - Discovered through leak detection
- **Hidden Losses**
 - Difference between Audit results and known failure volume





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Component Analysis Model - WRF 4372

WATER SUPPLIED

WATER SUPPLIED: 3,600.000 Acre-feet/Yr

AUTHORIZED CONSUMPTION

Billed Metered: 3,000.000 Acre-feet/Yr
Billed Unmetered: - Acre-feet/Yr
Unbilled Metered: - Acre-feet/Yr
Unbilled Unmetered: 10.000 Acre-feet/Yr

AUTHORIZED CONSUMPTION: 3,010.000 Acre-feet/Yr

WATER LOSSES: 590.000 Acre-feet/Yr

APPARENT LOSSES: 80.000 Acre-feet/Yr

REAL LOSSES: 510.000 Acre-feet/Yr

NON REVENUE WATER: 600.000 Acre-feet/Yr

SYSTEM DATA

Length of mains: 150.0 miles
Number of active AND inactive service connections: 9,000 service connections
Service connection density: 60.0 conn./mile main
Average length of customer service line*: - feet
Average operating pressure: 80.0 PSI

*Note: pipe length between curb stop and customer meter or point of first use for metered service connections

COST DATA



COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Component Analysis Model - WRF 4372

Mains by Size	Number of Leaks & Failures per Year	Length of Main miles	Failure Frequency (number / 100miles / yr)	Average Failure Flow Rate @ 70psi (gpm)	Average Pressure (psi)	N1 (Leakage- Pressure Exponent) Value	Average Failure Duration			Average Annual Loss per Failure (MG)	Total Annual Loss (MG)
							Average Awareness Duration (days)	Average Duration for Location and Repair/Shutoff Failure (days)	Total Duration (days)		
Diameter 2"	4	17.0	24	13.90	66.0	1.00	2.00	4.00	6.00	0.11	0.45
Diameter 3"	8	38.0	21	13.90	66.0	1.00	2.00	6.00	8.00	0.15	1.21
Diameter 4"	4	61.0	7	44.00	66.0	1.00	1.00	6.00	7.00	0.42	1.67
Diameter 6"	14	52.0	27	92.00	66.0	1.00	1.00	10.00	11.00	1.37	19.24
Diameter 8"	3	2.0	150	92.00	66.0	1.00	0.50	6.00	6.50	0.81	2.44
Diameter 10"	-	-	-	92.00	66.0	1.00	-	-	-	-	-

System Appurtenances by Type	Number of Failures per Year	Total Number of Appurtenances	Failure Frequency Number of Failures per 1000 Appurtenances	Average Failure Flow Rate @ 70psi (gpm)	Average Pressure (psi)	N1 (Leakage- Pressure Exponent) Value	Average Failure Duration			Average Annual Loss per Failure Acre-feet	Total Annual Loss Acre-feet
							Average Awareness Duration (days)	Average Duration for Location and Repair/Shutoff Failure (days)	Total Duration (days)		
Hydrants	4	200	20	3.50	80.0	1.00	10.00	5.00	15.00	0.27	1.06
Valves	5	1,000	5	6.90	80.0	1.00	15.00	10.00	25.00	0.87	4.36
Meters	8	10,000	1	0.25	80.0	1.00	25.00	20.00	45.00	0.06	0.45
Other (e.g. Blow-offs, etc.)	-	-	-	-	80.0	1.00	-	-	-	-	-

SUB-TOTAL REPORTED LEAKS ON SYSTEM APPURTENANCES 5.87



Component Analysis Model - WRF 4372

Data Required:

- Real Losses from Water Audit
- System Infrastructure Data
- Detailed Leak Repair Information

Systematic data handling errors: MG/Yr
Default option selected for Systematic data handling errors - a grading of 5 is applied but not displayed

Apparent Losses: MG/Yr

Real Losses (Current Annual Real Losses or CARL)

Real Losses = Water Losses - Apparent Losses: MG/Yr

WATER LOSSES: MG/Yr

NON-REVENUE WATER

NON-REVENUE WATER: MG/Yr
= Water Losses + Unbilled Metered + Unbilled Unmetered

SYSTEM DATA

Mains by Size	Number of Leaks & Failures per Year	Length of Main miles	Failure Frequency (number / 100miles / yr)	Average Failure Flow Rate @ 70psi (gpm)	Average Pressure (psi)	N1 (Leakage-Pressure Exponent) Value	Average Failure Duration			Average Annual Loss per Failure (MG)	Total Annual Loss (MG)
							Average Awareness Duration (days)	Average Duration for Location and Repair/Shutoff Failure (days)	Total Duration (days)		
Diameter 2"	4	17.0	24	13.90	66.0	1.00	2.00	4.00	6.00	0.11	0.45
Diameter 3"	8	38.0	21	13.90	66.0	1.00	2.00	6.00	8.00	0.15	1.21
Diameter 4"	4	61.0	7	44.00	66.0	1.00	1.00	6.00	7.00	0.42	1.67
Diameter 6"	14	52.0	27	92.00	66.0	1.00	1.00	10.00	11.00	1.37	19.24
Diameter 8"	3	2.0	150	92.00	66.0	1.00	0.50	6.00	6.50	0.81	2.44
Diameter 10"				92.00	66.0	1.00					



COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Component Analysis Model - WRF 4372

		<i>Unique ID# for failure or work order</i>
Minimum Required Information	Failure Event Type	<i>Reported - from complaints Unreported - from proactive leak detection</i>
	Service Connection Ownership Where Service Leak Occurred	<i>Utility Maintained Section Customer Maintained Section</i>
	General Location of Failure Event	<i>For Example - House Address</i>
	Size Information	<i>Service Connection Size</i>
	Failure Event Reported	<i>Date</i>
		<i>Time</i>
	Failure Event Pinpointed	<i>Date</i>
		<i>Time</i>
	Failure Event Contained/Valve- off/Repaired	<i>Date</i>
		<i>Time</i>



COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Component Analysis Model - WRF 4372

WaterRF 4372: Real Loss Component Analysis: A Tool for Economic Water Loss Control

REAL LOSSES COMPONENT ANALYSIS

SUMMARY: REAL LOSS COMPONENT ANALYSIS

System Component	Background Leakage (Acre-feet)	Reported Failures (Acre-feet)	Unreported Failures (Acre-feet)	Total (Acre-feet)
Reservoirs	4.03	-	-	4.03
Mains and Appurtenances	41.24	238.19	-	279.44
Service Connections	96.56	26.14	-	122.70
Total Annual Real Loss	141.84	264.33	-	406.17
Real Losses as Calculated by Water Audit				510.00
Hidden Losses/Unreported Leakage Currently Running Undetected				103.83



COLORADO

Colorado Water
Conservation Board

Department of Natural Resources




Component Analysis Model - WRF 4372

WaterRF 4372: Real Loss Component Analysis: A Tool for Economic Water Loss Control

REAL LOSSES COMPONENTS CHART

Real Loss Components






COLORADO

Colorado Water
Conservation Board


Department of Natural Resources




Component Analysis Model - WRF 4372



Mains Failure Frequency Comparison




Service Connection Failure Frequency Comparison





Managing Real Losses

- Based on types of leakage in the system
- Based on value of recoverable leakage
- Based on cost of leakage reduction interventions
- Determine implementation strategy






COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Intervention Strategies





COLORADO


Colorado Water
Conservation Board

Department of Natural Resources



Managing Real Losses

Surfaced Leak



Background Leakage



- Pressure management
- Main & service replacement
- Reduce # of joints and fittings

Unreported Leakage



- Pressure management
- Main & service replacement
- Reduce # of joints and fittings
- Proactive leakage program
- Optimized repair time

Reported Leakage



- Pressure management
- Main & service replacement
- Optimized repair time



COLORADO


Colorado Water
Conservation Board

Department of Natural Resources



Managing Real Losses

Improved Response Time





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Component Analysis Model - WRF 4372

Improved Response Time


Reported and Unreported Failure Events			
Failures on Mains			
	<i>Reported</i>	<i>Unreported</i>	
Total Failures on Mains	25	-	
Average location and repair duration	10.0	-	days
Total Volume lost (stemming from location and repair duration)	116.2	-	Acre-feet
Total Cost of Volume lost (stemming from location and repair duration)	\$ 58,081	\$ -	
What IF Location and Repair Duration is Reduced to	5		days
Percent Reduction	50%	0%	
Potential Related Savings in Leakage Volume	58.1	-	Acre-feet
Potential Related Savings in Leakage Volume Cost	\$ 29,040	\$ -	
Service Line Failures			
	<i>Reported</i>	<i>Unreported</i>	
Total Number of Failures on Service Connections	30	-	
Average location and repair duration	10.0	-	days
Total Volume lost (stemming from location and repair duration)	10.5	-	Acre-feet
Total Cost of Volume lost (stemming from location and repair duration)	\$ 5,227	\$ -	
What IF Location and Repair Duration is Reduced to	5		days
Percent Reduction	50%	0%	
Potential Related Savings in Leakage Volume	5.2	-	Acre-feet
Potential Related Savings in Leakage Volume Cost	\$ 2,614	\$ -	
Failures on System Appurtenances			
	<i>Reported</i>	<i>Unreported</i>	
Total Number of Failures on System Appurtenances	17	-	
Average location and repair duration	13.5	-	days
Total Volume lost (stemming from location and repair duration)	2.3	-	Acre-feet
Total Cost of Volume lost (stemming from location and repair duration)	\$ 1,149	\$ -	



Managing Real Losses

Active Leakage Control

- Proactive Leak Detection
- Leak Noise Loggers
- DMA Measurements





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Component Analysis Model - WRF 4372

Active Leakage Control

Variable Cost of Real Losses			
CV	Variable Production cost (applied to Real Losses):	1.53	\$/per kgal
		500.00	\$/Acre-ft
CI	Cost of comprehensive leak detection survey (excluding leak repair cost)	300.00	\$/per mile
		45,000	\$/for entire system
RR	Average Rate of Rise of Unreported Leakage	0.30	kgal/mile of mains/day in a year
		0.14	AF/day in a year
	CI/CV	195.5	kgal/mile
EIF	Economic Intervention Frequency $[0.789 * (CI/CV)/RR] ^{0.5}$	22.7	months
		689.7	days
	Economic Intervention Frequency - Average Leak Run Time	344.9	days
	Economic Percentage of System to be Surveyed per Year	53	%
ABI	Average Annual Budget for Intervention (Proactive Leak Detection)	23,814	\$/year
EUL	Economic Unreported Real Losses	15,520	kgal/year
		47.6	AF/year
	Economic Infrastructure Leakage Index (ILI)	2.6	



COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Managing Real Losses

Pressure Management





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Managing Real Losses

Pressure Management





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Managing Real Losses

Pressure Management





COLORADO


Colorado Water
Conservation Board

Department of Natural Resources



Managing Real Losses

Pressure Management





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Component Analysis Model - WRF 4372

Pressure Management

Pressure Management Opportunities

Existing Pressure Management Policy			
Current Average System Pressure	80.0	PSI	
Total Annual Real Losses	510.0	Acre-feet/Yr	
Value of Real Losses	255,000	\$/year	

FAVAD N1 Value Used for Calculation of Real Loss Reduction Due to Reduction of Average System Pressure

	☐ Use Default N1	1.0
	☒ Use System Specific N1	1.2
Enter % of rigid pipes and service connections in system	40%	
ILI	2.6	


Alternative Pressure Management Policy			
Assumed Reduction in Average System Pressure	5.0	PSI	
Assumed % Reduction in Average System Pressure	6%		
Real Loss Volume Saved Through Alternative Pressure Management Policy	38.0	Acre-feet/Yr	
Value of Real Loss Volume Saved Through Alternative Pressure Management Policy	18,984	\$/Year	
Enter Estimated Cost of Implementing Alternative Pressure Management Policy	20,000	\$	
Simple Payback Period for Implementing Alternative Pressure Management Policy	1.1	Years	



Managing Real Losses


Asset Management

- Create Inventory by Age, Size, Material, Etc.
- Failure Rates Affected by Multiple Factors




Source: Lambert, A. 2013 "Relationships between pressure, bursts and infrastructure life"

Real Loss Program Development

[illegible]

Reported and Unreported Failure Events				
Failures on Mains				
Total Failures on Mains	25	Reported	Unreported	
Average location and repair duration	10.0	-	days	
Total Volume lost (stemming from location and repair duration)	11.62	-	Acres-feet	
Total Cost of Volume Lost (stemming from location and repair duration)	\$ 58,810	-		
What If Location and Repair Duration is Reduced to				
Percent Reduction	50%	0%	days	
Potential Related Savings in Leakage Volume	5.8	-	Acres-feet	
Potential Related Savings in Leakage Volume Cost	\$ 29,405	-		
Service Line Failures				
Total Number of Failures on Service Connections	30	Reported	Unreported	
Average location and repair duration	10.0	-	days	
Total Volume lost (stemming from location and repair duration)	13.0	-	Acres-feet	
Total Cost of Volume Lost (stemming from location and repair duration)	\$ 5,227	-		
What If Location and Repair Duration is Reduced to				
Percent Reduction	50%	0%	days	
Potential Related Savings in Leakage Volume	5.2	-	Acres-feet	
Potential Related Savings in Leakage Volume Cost	\$ 2,614	-		
Failures on Service Connections				
Total Number of Failures on Service Connections	17	Reported	Unreported	
Average location and repair duration	13.5	-	days	
Total Volume lost (stemming from location and repair duration)	23.5	-	Acres-feet	
Total Cost of Volume Lost (stemming from location and repair duration)	\$ 1,495	-		





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources




Data Request for Component Analysis

- Completed Water Audit Software
- Reported Leak Repair Data
- Unreported Leak Repair Data
- Additional Infrastructure Data (# Valves, hydrants, etc)

		<i>Unique ID# for failure or work order</i>
Minimum Required Information	Failure Event Type	<i>Reported - from complaints Unreported - from proactive leak detection</i>
	Service Connection Ownership Where Service Leak Occurred	<i>Utility Maintained Section Customer Maintained Section</i>
	General Location of Failure Event	<i>For Example - House Address</i>
	Size Information	<i>Service Connection Size</i>
	Failure Event Reported	<i>Date</i>
		<i>Time</i>
	Failure Event Pinpointed	<i>Date</i>
		<i>Time</i>
	Failure Event Contained/Valve-off/Repaired	<i>Date</i>
		<i>Time</i>


Advanced Validation Methods & Technical Assistance: Leak Detection Survey

Types of Real Losses & Intervention Strategies





The Impact of Leak Run Times





COLORADO


Colorado Water
Conservation Board

Department of Natural Resources



Real Loss Management Strategies


Improved Response Time





Leak Survey


- Type of field investigation that uses specialized acoustic equipment to survey the water distribution system to locate non-surfacing leaks
- Select a portion or whole distribution system to check for leaks
 - Where to survey
 - How frequently
- During the survey, technicians listen to meters, service connections, hydrants, and valves throughout the water distribution system
- Depending on the complexity, other equipment or technologies may be employed to confirm and pinpoint the leak





Leak Survey

- Where to survey
 - If first survey, select areas based on operational knowledge:
 - Reported leak events
 - Older parts of the system
 - Low pressure reports
 - Unexplained bodies of water
 - Questionable contractor work
 - If previous surveys have been conducted
 - Areas not previously surveyed
 - Analysis of previous leak surveys
- How frequently
 - Depends on system condition and economics – costs of water lost and costs of intervention
 - Perform a component analysis of real losses
 - Analysis of results from leak surveys





Acoustic Leak Detection

- Walking survey with listening device
 - Listening Stick
 - Geophone
 - Electronic Sounding Instrument
- Leak noise correlators & hydrophones
- Noise loggers
- Line locators
- Metal detectors





COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



- **Leak Sound Characteristics:**
 - Pipe Wall – higher frequency, shorter travel
 - “Escaping” Water – lower frequency, travels farther
 - Impact – lower frequency, water impacting cavity walls and rocks circulating in cavity
 - Continuous – leak sound is continuous unlike transient ambient noises
- **Factors Affecting Leak Sound:**
 - System Pressure
 - Pipe Material & Size
 - Background Noise
 - Type Of Leak
 - Surface Covering Pipes



COLORADO

Colorado Water
Conservation Board

Department of Natural Resources




- Sources Of Interference
 - Traffic & Other Equipment Noise
 - Variation of Soil Moisture & Water Table
 - Variation of Surface Materials
 - Variation of Depth
 - Variation of Soil Properties
 - Variation in Pipe Bedding Materials
 - Low Pressure in Pipe
 - Radio Frequency Interference
- Non-Leak Sound Sources (“False Positives”):
 - Gas lines
 - Repair couplings
 - PRVs
 - Force mains
 - Consumption
 - Meter noise
 - Partially closed or broken valves
 - Active blow-offs



1

2

3





- Methods to verify leaks
 - Visible water
 - Chlorine test
 - Shut-off water service (for leaks suspected on service line or customer meter)
 - Operating hydrants or valves
 - Leak noise correlation
 - Excavation
- We make every effort possible to find the exact location of the leak. However, unknown conditions underground may cause the leak to appear to be some distance from the real location. Marked leak locations may have a margin of error of 5-8 feet.
- If during the excavation, the utility is having trouble locating a reported leak, WSO technicians can assist during the excavation



COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



PHONE: 913.431.3722

PHONE: 913.431.3730

LEAK REPORT

Date: October 15, 2021

Report #: 51

Survey ☒

Recheck ☐

Location Error ☐

Request ☐

LOCATION

Address: 570 W Eastland St, Gallatin, Tennessee, 37066

Cross Street: Roosevelt Cir

Grid Map: 47

DETAILS

ESTIMATION: GPM 10

COVER: Asphalt

COMMENT Correlation: Sensor A (valve 113-O-15) to Sensor B (valve 113-O-16)
S:


PRIORITY:

TECHNICIAN: U Navarro, C Bracy

Suspected On: Main

Indication: Sonic,
Correlation, Visual Water

ID:




Leak Report



COLORADO

Colorado Water
Conservation Board

Department of Natural Resources



Leak Reports



COLORADO


Colorado Water
Conservation Board

Department of Natural Resources



Results of
recent survey
~65 miles

INFRASTRUCTURE TYPE	COUNT OF LEAKS	% OF TOTAL LEAKS	ESTIMATED FLOW RATE (GPM)	% OF TOTAL FLOW RATE
Main	5	18%	33	31%
Service	12	43%	38	36%
Meter	5	18%	6	6%
Hydrant	6	21%	30	28%
TOTAL	28	100%	107	100%






COLORADO

Colorado Water
Conservation Board


Department of Natural Resources




All Leaks/100 miles of main



Main Leaks/100 miles of main



Service & Meter Leaks/1,000 customers





Leak Survey Data Request

GIS files or
maps:

- Pipe Material
- Size
- Asset Type

