

WELL PERMIT NUMBER 79579 -F -
DIV. 6 WD 44 DES. BASIN MD

APPLICANT

WAGNER ROCK LLC
96400 E HWY 40
CRAIG, CO 81625-

(970) 629-2252

APPROVED WELL LOCATION

MOFFAT COUNTY

SE 1/4 NE 1/4 Section 6
Township 6 N Range 90 W Sixth P.M.

DISTANCES FROM SECTION LINES

Ft. from Section Line
Ft. from Section Line

UTM COORDINATES (Meters, Zone: 13, NAD83)

Easting: Northing:

PERMIT TO EXPOSE WATER IN A PIT

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-90-137 (2) and (11), for the use of a well (gravel pit pond) exposing ground water tributary to the Yampa River at a point where water is available for appropriation. This well is known as the Wagner Pit, Division of Reclamation, Mining & Safety Permit Number M-2010-002.
- 4) The approval of this permit does not grant a water right. This well (gravel pit pond) is subject to administration by the Division Engineer in accordance with applicable decrees, statutes, rules and regulations.
- 5) The average annual amount of ground water to be appropriated shall not exceed 21.0 acre-feet with the total surface area of the proposed gravel pit pond limited to 7.0 acres.
- 6) The use of ground water is limited to evaporation off of a gravel pit pond. No other use of water is allowed unless a permit therefor is approved.
- 7) The owner shall mark the well (gravel pit pond) in a conspicuous place with well permit number(s) and court case number(s) as appropriate. The owner shall take necessary means and precautions to preserve these markings.
- 8) Pursuant to Policy 2014-1 of the State Board of Examiners of Water Well Construction and Pump Installation Contractors (Board), the minimum construction standards in Rule 10 of the Water Well Construction Rules shall be waived for gravel pit ponds, except, compliance with Rule 10 1 and its subsections 10.1.2, 10.1.4, 10.1.6 and Rule 10.2 and its subsection 10.2.1 is required. The owner of the gravel pit pond shall take necessary means and precautions to prevent contaminants from entering the gravel pit pond.
- 9) The boundaries of the gravel pit pond shall be more than 600 feet from any existing well, completed in the same aquifer, that is not owned by the applicant.

NOTE: This well may be subject to administration in the water rights priority system in the future. It is recommended that a water court decree be obtained to affirm the priority of the well. *JP 1/4/16*

APPROVED
JSG

State Engineer

DATE ISSUED 01-04-2016

By

EXPIRATION DATE *N/A*

Receipt No. 3672113