

DMR Copy of Record

Permit		Permittee:		Facility:									
Permit #:	CO0038024	Blue Mountain Energy Inc		DESERADO MINE									
Major:	No	10714 S Jordan Gateway Ste 300 South Jordan, UT 84095		3807 CR 85 RIO BLANCO COUNTY, CO 81648									
Permitted Feature:		Discharge:											
001 External Outfall		001-A DP-1 SEDI POND TO SCULLION GUL											
Report Dates & Status		DMR Due Date:		Status:									
Monitoring Period: From 01/01/21 to 03/31/21		04/28/21		NetDMR Validated									
Considerations for Form Completion													
TSS & TOTAL IRON LIMITS WILL BE WAIVED FOR 10YR 24HR RECIP EVENT - SEE IA 1, PG 3 FOR REQUIREMENTS OIL & GREASE REPORTING = I.B.I.A.PG 13 QTRLY SAMPLING INSTRUCTIONS - I.C.7, PG 14													
Principal Executive Officer		Title:		Telephone:									
First Name: Phillip		Vice-President Chief Engineer		801-619-8560									
Last Name: Solomon													
No Data Indicator (NOD)													
Parameter Name	Monitoring Location	Season	Param. NOD	Qualifier	Value 1	Qualifier	Value 2	Qualifier	Value 3	Units	# of Ea.	Frequency of Analysis	Sample Type
00400 pH	1 - Effluent Gross	0	-									02/20 - Twice Per Month	IS - INSTU
					7.5								
					6.5 MINIMUM							01/20 - Monthly	IS - INSTU
00530 Solids, total suspended	1 - Effluent Gross	0	-									01/20 - Quarterly	GR - GRAB
					22.0								
					31.9 300A AVG							01/20 - Quarterly	GR - GRAB
00545 Solids, settleable	1 - Effluent Gross	0	-									01/20 - Quarterly	GR - GRAB
												01/20 - Quarterly	GR - GRAB
01045 Iron, total [as Fe]	1 - Effluent Gross	0	-									01/20 - Quarterly	GR - GRAB
												01/20 - Quarterly	GR - GRAB
03582 Oil and grease	1 - Effluent Gross	0	-									7/1/77 - Contingent	GR - GRAB
50050 Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	-									02/20 - Twice Per Month	IN - INSTAN
					0.032								
					Reg Mon 300A							01/20 - Monthly	IN - INSTAN
					0.78 DAILY MX AVG								
70295 Solids, total dissolved	1 - Effluent Gross	0	-									01/20 - Quarterly	GR - GRAB
												01/20 - Quarterly	GR - GRAB
84006 Oil and grease visual	1 - Effluent Gross	0	-									01/20 - Quarterly	VI - VISUAL
												01/20 - Quarterly	VI - VISUAL

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

Blue Mountain Energy Inc

User:

Name:

E-Mail:

Date/Time:

Report Last Signed By

User:

Name:

E-Mail:

Date/Time:

kblunt@tristategl.org

Kurtis Blunt

kblunt@deserado.com

2021-04-15 10:49 (Time Zone -06 00)

PSOLOMON1958

PHILLIP SOLOMON

psolomon@deserepower.com

2021-04-22 16:45 (Time Zone -06 00)

DMR Copy of Record

Permit	Permit #: C00038024	Permittee: Blue Mountain Energy Inc	Facility: DESERADO MINE
Major:	No	Permittee Address: 10714 S Jordan Gateway Ste 300 South Jordan, UT 84095	Facility Location: 3607 CR 65 RIO BLANCO COUNTY, CO 81648
Permitted Feature:	002 External Outfall	Discharge: 002-A RF-1 SEDI POND TO RED WASH	
Report Dates & Status		DMR Due Date: 04/28/21	Status: NotDMR Validated
Monitoring Period:	From 01/01/21 to 03/31/21		
Considerations for Form Completion	TSS & TOTAL IRON LIMITS WILL BE WAIVED FOR 10YR 24HR RECIP EVENT - SEE I.A.1.PG 3. FOR REQUIREMENTS OIL & GREASE REPORTING - I.B.1.A.PG 13. QTRLY SAMPLING INSTRUCTIONS - IC.1.7. PG 14.		
Principal Executive Officer			
First Name: Philip	Title: Vice-President Chief Engineer		
Last Name: Solomon			Telephone: 801-619-6560
No Data Indicator (NOD)			

Code	Parameter Name	Monitoring Location	Season #	Param. NOD	Quantity or Loading		Quality or Concentration		Frequency of Analysis	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3
00400	pH	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD	6.5 MINIMUM C - No Discharge	>=	9.0 MAXIMUM C - No Discharge	12 - SU	0230 - Twice Per Month GR - GRAB
00530	Solids, total suspended	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD	35.0 30DA AVG C - No Discharge	<=	70.0 MX 7D AV C - No Discharge	19 - mg/L	0230 - Twice Per Month GR - GRAB
00545	Solids, settleable	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD		<=	0.5 DAILY MX C - No Discharge	25 - mL/L	0230 - Twice Per Month GR - GRAB
01045	Iron, total [as Fe]	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD	3.5 30DA AVG C - No Discharge	<=	7.0 DAILY MX C - No Discharge	19 - mg/L	0230 - Twice Per Month GR - GRAB
03502	Oil and grease	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD		<=	10.0 INST MAX C - No Discharge	19 - mg/L	7177 - Contingent GR - GRAB
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD	Req Mon 30DA AVG C - No Discharge		Req Mon DAILY MX C - No Discharge	03 - MGD	0100 - Monthly IN - INSTAN
70295	Solids, total dissolved	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD			Req Mon QTR AVG C - No Discharge	19 - mg/L	0190 - Quarterly GR - GRAB
84066	Oil and grease visual	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD			Req Mon INST MAX C - No Discharge	9P - Inst Y+1	0230 - Twice Per Month VI - VISUAL

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors

Comments

Attachments
No attachments.

Report Last Saved By
Blue Mountain Energy Inc

User: kbunt@tristatag.org
Name: Kurtis Blunt
E-Mail: kbunt@deserado.com
Date/Time: 2021-04-15 10:50 (Time Zone -06:00)

Report Last Signed By

User:

Name

E-Mail:

Date/Time

PSOLOMON1958

PHILLIP SOLOMON

psolomon@deserepower.com

2021-04-22 18:45 (Time Zone -06:00)

DMR Copy of Record

Permit		Permittee:		Facility:												
Permit #:	CO0038024	Blue Mountain Energy Inc		DESERADO MINE												
Major:	No	10714 S Jordan Gateway Ste 300		3807 CR 05												
		South Jordan, UT 84095		RIO BLANCO COUNTY, CO 81648												
Permitted Feature:		Discharge:														
003 External Outfall		RP-243 SEDI POND TO RED WASH														
Report Dates & Status		DMR Due Date:		Status:												
Monitoring Period: From 01/01/21 to 03/31/21		04/29/21		NetDMR Validated												
TSS & TOTAL IRON LIMITS WILL BE WAIVED FOR 10YR, 24HR RECIP EVENT - SEE I.A.1, PG. 3 FOR REQUIREMENTS OIL & GREASE REPORTING - I.B.1.A, PG. 13 QTRLY SAMPLING INSTRUCTION - I.C.7, PG. 14.																
Principal Executive Officer																
First Name:		Title:		Telephone:												
Phillip		Vice-President Chief Engineer		801-619-6560												
Last Name:																
Solomon																
No Data Indicator (NODI)																
Form NODI:																
Code	Parameter Name	Monitoring Location	Season	Param. NODI	Sample Permit Req. Value NODI	Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 3	Value 3	Units	# of Ex.	Frequency of Analysis	Sample Type
00400	pH	1 - Effluent Gross	0	-												
00530	Solids, total suspended	1 - Effluent Gross	0	-												
00545	Solids, settleable	1 - Effluent Gross	0	-												
01045	Iron, total [as Fe]	1 - Effluent Gross	0	-												
01502	Oil and grease	1 - Effluent Gross	0	-												
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	-												
70295	Solids, total dissolved	1 - Effluent Gross	0	-												
84066	Oil and grease visual	1 - Effluent Gross	0	-												
Submission Note																
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																
Edit Check Errors																
No errors																
Comments																
Attachments																
No attachments.																
Report Last Saved By																
Blue Mountain Energy Inc																
User																
Kurtis Blunt																
Name																
kblunt@tristategr.org																
E-Mail:																
kblunt@desorodo.com																
Date/Time:																
2021-04-15 10:51 (Time Zone -06:00)																

Report Last Signed By

User:

Name:

E-Mail:

Date/Time:

PSOLOMON1958

PHILLIP SOLOMON

psolomon@deserelpower.com

2021-04-22 16:45 (Time Zone: -06:00)

DMR Copy of Record

Permit		CO0038024		Blue Mountain Energy Inc		DESERADO MINE	
Permit #:		No		10714 S Jordan Gateway Ste 300		3807 CR 65	
Major:		004 External Outfall		South Jordan, UT 84095		RIO BLANCO COUNTY, CO 81648	
Permitted Feature:		004 External Outfall		004-A PP2 TO SCULLION GULCH			
Report Dates & Status		From 01/01/21 to 03/31/21		04/28/21		NeDMR Validated	
Monitoring Period:		Oil & GREASE REPORTING-SEE I.B.1.A, PG 13 QTRLY SAMPLING INSTRUCTIONS I.C.7, PG. 14					
Principal Executive Officer		Phillip Solomon		Vice-President Chief Engineer		801-619-6560	
First Name:		Phillip					
Last Name:		Solomon					
No Data Indicator (NOD)							
Form NOD:							

Code	Parameter Name	Monitoring Location	Season	Param. NOD	Sample Permit Req. Value NOD	Qualifier 1	Value 1	Quantity or Loading	Qualifier 2	Value 2	Units	Qualifier 3	Value 3	Units	# of Ex.	Frequency of Analysis	Sample Type
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD	Qualifier 1	Value 1	Quantity or Loading	Qualifier 2	Value 2	Units	Qualifier 3	Value 3	Units			
						7.2 30DA AVG					26 - lpd		45.0 MX 7D AV	19 - mg/L	0230 - Twice Per Month	GR - GRAB	
						C - No Discharge					C - No Discharge		C - No Discharge				
00400	pH	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD								9.0 MAXIMUM	12 - SU	0230 - Twice Per Month	IS - INSTITU	
											6.5 MINIMUM		C - No Discharge				
00530	Solids, total suspended	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD								70.0 MX 7D AV	19 - mg/L	0230 - Twice Per Month	GR - GRAB	
													C - No Discharge				
00545	Solids, settleable	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD								0.5 DAILY MX	25 - mL/L	0230 - Twice Per Month	GR - GRAB	
													C - No Discharge				
01045	Iron, total [as Fe]	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD								7.0 DAILY MX	19 - mg/L	0230 - Twice Per Month	GR - GRAB	
													C - No Discharge				
03592	Oil and grease	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD								10.0 INST MAX	19 - mg/L	7777 - Contingent	GR - GRAB	
													C - No Discharge				
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD										0130 - Monthly	IN - INSTAN	
						Req Mon 30DA AVG					0.042 DAILY MX						
						C - No Discharge					C - No Discharge						
50060	Chlorine, total residual	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD								0.5 DAILY MX	19 - mg/L	0230 - Twice Per Month	GR - GRAB	
													C - No Discharge				
70295	Solids, total dissolved	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD								Req Mon DAILY MX	19 - mg/L	0190 - Quarterly	GR - GRAB	
													C - No Discharge				
74055	Calform, fecal general	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD								4000.0 30DAVGE0	13 - #/100mL	0230 - Twice Per Month	GR - GRAB	
													C - No Discharge				
84066	Oil and grease visual	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD								Req Mon INST MAX	9P - N+Q, Y+1	0230 - Twice Per Month	VI - VISUAL	
													C - No Discharge				

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

Blue Mountain Energy Inc

User:

Name:

E-Mail:

Date/Time:

kblunt@tristategl.org

Kurtis Blunt

kblunt@deserado.com

2021-04-15 10:51 (Time Zone: -06:00)

Report Last Signed By

User:

Name:

E-Mail:

Date/Time:

PSOLOMON1958

PHILLIP SOLOMON

psolomon@deseretpower.com

2021-04-22 16:45 (Time Zone: -06:00)

DMR Copy of Record

Permit		Permit #: CO0038024		Permittee: Blue Mountain Energy Inc		Facility: DESERADO MINE	
Major: No		Permittee Address: 10714 S Jordan Gateway Ste 300 South Jordan, UT 84095		Facility Location:		3607 CR 65 RIO BLANCO COUNTY, CO 81648	
Permitted Feature: 004 External Outfall		Discharge:		004-W ACUTE WET TESTING FOR 004A			
Report Dates & Status				Status: Not DMR Validated			
Monitoring Period: From 01/01/21 to 03/31/21		DMR Due Date: 04/28/21					
Considerations for Form Completion							
SEE PART I.A.2, PG 8-10 FOR DETAILS OF TEST PROCEDURE REPORT LC50- STATISTICAL POINT ESTIMATE WHICH IS LETHAL TO 50% OF TEST ORGANISMS. AND ATTACH ACUTE TOXICITY TEST REPORT FORM TO DMR							
Principal Executive Officer							
First Name: Phillip		Title: Vice-President Chief Engineer		Telephone: 801-619-6560			
Last Name: Solomon							
No Data Indicator (NODI)							
Form NODI: -							
Parameter Name		Monitoring Location Season & Param. NODI		Quantity or Loading		Quality or Concentration	
				Qualifier 1 Value 1		Qualifier 2 Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	
				Qualifier 1		Qualifier 2	
				Value 1		Value 2	

DMR Copy of Record

Permit		CO0038024		Blue Mountain Energy Inc 10714 S Jordan Gateway Ste 300 South Jordan, UT 84095		Facility: DESERADO MINE 3607 CR 65 RIO BLANCO COUNTY, CO 81648		
Major:		No		Permittee Address:		Facility Location:		
Permitted Feature:		005 External Outfall		Discharge:		005-A RR-1 LOADOUT TO RED WASH		
Report Dates & Status		From 01/01/21 to 03/31/21		DMR Due Date:		04/28/21		
Monitoring Period:		From 01/01/21 to 03/31/21		Status:		Not DMR Validated		
Considerations for Form Completion		TSS & TOTAL IRON LIMITS WILL BE WAIVED FOR 10YR 24HR PRECIP EVENT - SEE LA 1, PG 3 FOR REQUIREMENTS OIL & GREASE REPORTING - LB 1, PG 13 ORTRLY SAMPLING INSTRUCTIONS - LC 7, PG 14.						
Principal Executive Officer		Philip Solomon		Title:		Vice-President Chief Engineer		
First Name:		Philip		Title:		Vice-President Chief Engineer		
Last Name:		Solomon		Telephone:		801-619-6560		
No Data Indicator (NODI)		-		Form NODI:		-		
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Sample Permit Req. Value NODI	Quantity or Loading Qualifier 1 Value 1 Qualifier 2 Value 2 Units	Quality or Concentration Qualifier 3 Value 3 Qualifier 4 Value 4 Units	# of Ex. Frequency of Analysis Sample Type
00400	pH	1 - Effluent Gross	0	-	-	>= 6.5 MINIMUM C - No Discharge	<= 9.0 MAXIMUM C - No Discharge	12 - SU 0220 - Twice Per Month GR - GRAB
00530	Solids, total suspended	1 - Effluent Gross	0	-	-	<= 35.0 30DA AVG C - No Discharge	<= 70.0 MX 7D AV C - No Discharge	19 - mg/L 0220 - Twice Per Month GR - GRAB
00545	Solids, settleable	1 - Effluent Gross	0	-	-	<= 0.5 DAILY MX C - No Discharge	<= 25 - mL/L	0220 - Twice Per Month GR - GRAB
01045	Iron, total [as Fe]	1 - Effluent Gross	0	-	-	<= 3.5 30DA AVG C - No Discharge	<= 7.0 DAILY MX C - No Discharge	19 - mg/L 0220 - Twice Per Month GR - GRAB
03502	Oil and grease	1 - Effluent Gross	0	-	-	<= 10.0 INST MAX C - No Discharge	<= 19 - mg/L	7777 - Contingent GR - GRAB
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	-	-	Req Mon 30DA AVG C - No Discharge	Req Mon DAILY MX C - No Discharge	0120 - Monthly IN - INSTAN
70295	Solids, total dissolved	1 - Effluent Gross	0	-	-	Req Mon QTRTR AVG C - No Discharge	Req Mon DAILY MX C - No Discharge	0150 - Quarterly GR - GRAB
84066	Oil and grease visual	1 - Effluent Gross	0	-	-	Req Mon INST MAX 9P - 1400 Y=1 C - No Discharge	Req Mon INST MAX 9P - 1400 Y=1 C - No Discharge	0220 - Twice Per Month VI - VISUAL

Submission Note
If a parameter row does not contain any values for the Sample not Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments
No attachments.

Report Last Saved By
Blue Mountain Energy Inc

User
User

Name
Kurtis Blunt

E-Mail:
kblunt@deserado.com

Date/Time:
2021-04-15 10:53 (Time Zone -06:00)

Report Last Signed By

User:

PSOLOMON1958

Name:

PHILLIP SOLOMON

E-Mail:

psolomon@deseretpower.com

Date/Time:

2021-04-22 16:45 (Time Zone -06:00)

DMR Copy of Record

Permit		CO0038024		Blue Mountain Energy Inc		DESERADO MINE									
Permit #:		No		10714 S Jordan Gateway Ste 300		3607 CR 65									
Major:				South Jordan, UT 84095		RIO BLANCO COUNTY, CO 81648									
Permitted Feature:		008 External Outfall		008-A SS-1 SLOT STORAGE TO RED WASH											
Report Dates & Status		From 01/01/21 to 03/31/21		04/28/21		NetDMR Validated									
Monitoring Period:															
Considerations for Form Completion		TSS & TOTAL IRON LIMITS WILL BE WAIVED FOR 10YR 24HR PRECIP EVENT - SEE I.A.1, PG. 3. FOR REQUIREMENTS OIL & GREASE REPORTING - I.B.1.A PG. 13 QTRTLY SAMPLING INSTRUCTIONS - I.C.7. PG. 14.													
Principal Executive Officer		Philip Solomon		Vice-President Chief Engineer		801-619-6560									
First Name:		Philip													
Last Name:		Solomon													
Title:															
No Data Indicator (NODI)															
Form NODI:															
Code	Parameter Name	Monitoring Location	Season	Permit NODI	Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 3	Value 3	Units	# of Ex.	Frequency of Analysis	Sample Type
00400	pH	1 - Effluent	Gross	0	-		>=	6.5 MINIMUM	C - No Discharge	<=	9.0 MAXIMUM	12 - SU		0230 - Twice Per Month	IS - INSITU
00530	Solids, total suspended	1 - Effluent	Gross	0	-		<=	35.0 30DA AVG	C - No Discharge	<=	70.0 MX 7D AV	19 - mg/L		0230 - Twice Per Month	GR - GRAB
00545	Solids, settleable	1 - Effluent	Gross	0	-		<=	0.5 DAILY MX	C - No Discharge	<=	0.5 DAILY MX	25 - mL/L		0230 - Twice Per Month	GR - GRAB
01045	Iron, total [as Fe]	1 - Effluent	Gross	0	-		<=	3.0 30DA AVG	C - No Discharge	<=	6.0 DAILY MX	19 - mg/L		0230 - Twice Per Month	GR - GRAB
03592	Oil and grease	1 - Effluent	Gross	0	-		<=	10.0 INST MAX	C - No Discharge	<=	10.0 INST MAX	19 - mg/L		7777 - Contingent	GR - GRAB
50050	Flow, in conduit or thru treatment plant	1 - Effluent	Gross	0	-			Req Mon 30DA AVG	C - No Discharge		03 - MGD			0130 - Monthly	IN - INSTAN
70295	Solids, total dissolved	1 - Effluent	Gross	0	-			Req Mon GRTR AVG	C - No Discharge		Req Mon DAILY MX	19 - mg/L		0180 - Quarterly	GR - GRAB
84066	Oil and grease /visual	1 - Effluent	Gross	0	-			Req Mon INST MAX	SP - Inst, Y=1					0230 - Twice Per Month	VI - VISUAL
Submission Note If a parameter row does not contain any values for the Sample or Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.															
Edit Check Errors No errors.															
Comments No attachments.															
Attachments Report Last Saved By Blue Mountain Energy Inc															
User: kkhunt@strategi.org Name: Kurtis Blunt E-Mail: kkhunt@deserado.com Date/Time: 2021-04-15 10:54 (Time Zone -06:00)															

Report Last Signed By

User:

Name:

E-Mail:

Date/Time:

PSOLOMON1958

PHILLIP SOLOMON

psolomon@deseripower.com

2021-04-22 16:45 (Time Zone: -06:00)

DMR Copy of Record

Permit		Permit #: CO0038024		Permittee: Blue Mountain Energy Inc		Facility: DESERADO MINE						
Major:		No		Permittee Address: 10714 S Jordan Gateway Ste 300 South Jordan, UT 84095		Facility Location: 3807 CR 85 RIO BLANCO COUNTY, CO 81848						
Permitted Feature:		009 External Outfall		Discharge: 009-A SS-2 SLOT STORAGE TO RED WASH								
Report Dates & Status		From 01/01/21 to 03/31/21		DMR Due Date: 04/28/21		Status: NetDMR Validated						
Monitoring Period: TSS & TOTAL IRON LIMITS WILL BE WAIVED FOR 10YR,24HR PRECIP EVENT - SEE I.A, PG.3 FOR REQUIREMENTS OIL & GREASE REPORTING - I.B I.A, PG.13 QTRTRY SAMPLING INSTRUCTIONS - I.C.7 - PG.14.												
Principal Executive Officer First Name: Phillip Last Name: Solomon Title: Vice-President Chief Engineer Telephone: 801-619-8580												
No Data Indicator (NODI) Form NODI:												
Code	Parameter Name	Monitoring Location Screen # Param. NODI	Sample Permit Req. Value NODI	Qualifier 1	Value 1	Quantity or Loading Qualifier 2	Value 2	Units	Qualifier 3	Value 3	Units	# of Ex. Frequency of Analysis Sample Type
00400	pH	1 - Effluent Gross	0	-		>=	6.5 MINIMUM C - No Discharge		<=	9.0 MAXIMUM C - No Discharge	12 - SLJ	0107 - Weekly GR - GRAB
00530	Solids, total suspended	1 - Effluent Gross	0	-		<=	35.0 30DA AVG C - No Discharge		<=	70.0 MX 7D AV C - No Discharge	19 - mg/L	0120 - Monthly GR - GRAB
00545	Solids, settleable	1 - Effluent Gross	0	-					<=	0.5 DAILY MX C - No Discharge	25 - mL/L	0120 - Monthly GR - GRAB
01045	Iron, total [as Fe]	1 - Effluent Gross	0	-		<=	3.0 30DA AVG C - No Discharge		<=	6.0 DAILY MX C - No Discharge	19 - mg/L	0120 - Monthly GR - GRAB
03552	Oil and grease	1 - Effluent Gross	0	-					<=	10.0 INST MAX C - No Discharge	19 - mg/L	7777 - Contingent GR - GRAB
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	-		Req Mon 30DA AVG C - No Discharge	0.2 DAILY MX C - No Discharge	03 - MGD				0107 - Weekly IN - INSTAN
70295	Solids, total dissolved	1 - Effluent Gross	0	-						Req Mon QTRTR AVG C - No Discharge	19 - mg/L	0120 - Quarterly GR - GRAB
84066	Oil and grease Visual	1 - Effluent Gross	0	-		Req Mon INST MAX C - No Discharge		9P - 1400 Y=1				0220 - Twice Per Month VI - VISUAL

Submission Note
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
 No errors

Comments

Attachments
 No attachments

Report Last Saved By
 Blue Mountain Energy Inc

User: kbhuni@ursstrategi.org
Name: Kurtis Blunt
E-Mail: kbhuni@deserado.com
Date/Time: 2021-04-15 10:55 (Time Zone -06:00)

Report Last Signed By

User: PSOLOMON1558
Name: PHILLIP SOLOMON
E-Mail: psolomon@desertpower.com
Date/Time: 2021-04-22 18:45 (Time Zone -06:00)

DMR Copy of Record

Permit		CO0038024		Blue Mountain Energy Inc		Facility:		DESERADO MINE							
Permit #:		No		10714 S Jordan Gateway Site 300		Facility Location:		3807 CR 85							
Major:		025		South Jordan, UT 84095				RIO BLANCO COUNTY, CO 81848							
Permitted Feature:		025 External Outfall		025-A		Discharge:		RP4 SEDI POND TO RED WASH							
Report Dates & Status		From 01/01/21 to 03/31/21		04/23/21		Status:		NetDMR Validated							
Monitoring Period:		Considerations for Form Completion													
TSS & TOTAL IRON LIMITS WILL BE WAIVED FOR 10YR:24HR PRECIP. EVENT - SEE I.A.1, PG. 3 FOR REQUIREMENTS.OIL & GREASE REPORTING - I.B.1.A, PG.13 QTRTRY SAMPLING INSTRUCTIONS - I.C.7., PG. 14															
Principal Executive Officer		Phillip Solomon		Vice-President Chief Engineer		Title:		801-619-6560							
First Name:		Phillip													
Last Name:		Solomon													
No Data Indicator (NODI)		-													
Form NODI:															
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Sample Permit Req. Value NODI	Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 3	Value 3	Units	# of Ex. Frequency of Analysis	Sample Type
00400	pH	1 - Effluent Gross	0	-		>=	6.5 MINIMUM C - No Discharge				<=	9.0 MAXIMUM C - No Discharge	12 - SU	0220 - Times Per Month	GR - GRAB
00530	Solids, total suspended	1 - Effluent Gross	0	-				<=	35.0 30DA AVG C - No Discharge			70.0 MX 7D AV C - No Discharge	19 - mg/L	0220 - Times Per Month	GR - GRAB
00545	Solids, settleable	1 - Effluent Gross	0	-							<=	0.5 DAILY MX C - No Discharge	25 - mL/L	0220 - Times Per Month	GR - GRAB
01045	Iron, total [as Fe]	1 - Effluent Gross	0	-				<=	3.5 30DA AVG C - No Discharge			7.0 DAILY MX C - No Discharge	19 - mg/L	0220 - Times Per Month	GR - GRAB
03582	Oil and grease	1 - Effluent Gross	0	-							<=	10.0 INST MAX C - No Discharge	19 - mg/L	7777 - Contingent	GR - GRAB
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	-					Req Mon DAILY MX 03 - MGD C - No Discharge					0120 - Monthly	IN - INSTAN
70295	Solids, total dissolved	1 - Effluent Gross	0	-								Req Mon DAILY MX C - No Discharge	19 - mg/L	0120 - Quarterly	GR - GRAB
84066	Oil and grease visual	1 - Effluent Gross	0	-					Req Mon INST MAX 9P - Inst Y+1 C - No Discharge					0220 - Times Per Month	VI - VISUAL

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type

Edit Check Errors
No errors.

Comments

Attachments
No attachments.

Report Last Saved By
Blue Mountain Energy Inc

User
Kurtis Blunt

Name
kblunt@desorado.com

E-Mail
kblunt@tristatetg.org

Date/Time
2021-04-15 10:55 (Time Zone -06:00)

Report Last Signed By

User:

Name:

E-Mail:

Date/Time:

PSOLOMON1958

PHILLIP SOLOMON

psolomon@desanipower.com

2021-04-22 16:45 (Time Zone: -06:00)

DMR Copy of Record

Permit		Permittee:		Facility:				
Permit #:	CO0038024	Blue Mountain Energy Inc		DESERADO MINE				
Major:	No	10714 S Jordan Gateway Ste 300 South Jordan, UT 84095		3807 CR 65 RIO BLANCO COUNTY, CO 81648				
Permitted Feature:		Discharge:						
026 External Outfall		026-A SDH35 SEDI POND TO RED WASH						
Report Dates & Status		DMR Due Date:		Status:				
Monitoring Period: From 01/01/21 to 03/31/21		04/28/21		NetDMR Validated				
TSS & TOTAL IRON LIMITS WILL BE WAIVED FOR 10YR 24HR PRECIP. EVENT - SEE I.A.1, PG. 3, FOR REQUIREMENTS OIL & GREASE REPORTING - I.B.1.A, PG. 13, QTRLY SAMPLING INSTRUCTIONS - I.C.7, PG. 14								
Principal Executive Officer								
First Name:		Title:		Telephone:				
Phillip Solomon		Vice-President Chief Engineer		801-619-6560				
Last Name:								
Solomon								
No Data Indicator (NODI)								
Form NODI:								
Parameter Name		Monitoring Location Season & Param. NODI		# of Ex. Frequency of Analysis Sample Type				
Code	Parameter Name	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units
00400	pH	1 - Effluent Gross	0	-				12 - SU
00530	Solids, total suspended	1 - Effluent Gross	0	-				9.0 MAXIMUM C - No Discharge
00545	Solids, settleable	1 - Effluent Gross	0	-				70.0 MX 7D AV C - No Discharge
01045	Iron, total [as Fe]	1 - Effluent Gross	0	-				0.5 DAILY MX C - No Discharge
03582	Oil and grease	1 - Effluent Gross	0	-				10.0 INST MAX C - No Discharge
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	-				6.0 DAILY MX C - No Discharge
70295	Solids, total dissolved	1 - Effluent Gross	0	-				77777 Contingent GR - GRAB
84066	Oil and grease visual	1 - Effluent Gross	0	-				99999 Continuous IN - INSTANT
Submission Note								
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.								
Edit Check Errors								
No errors.								
Comments								
Attachments								
No attachments.								
Report Last Saved By								
Blue Mountain Energy Inc								
User:								
Name:								
E-Mail:								
Date/Time:								

Report Last Signed By

User:

Name

E-Mail:

Date/Time:

PSOLOMON1958

PHILLIP SOLOMON

psolomon@deseripower.com

2021-04-22 18:45 (Time Zone -05:00)

DMR Copy of Record

Permit		Permittee:		Facility:	
Permit #:	CO0038024	Blue Mountain Energy Inc	DESERADO MINE		
Major:	No	10714 S Jordan Gateway Ste 300	3607 CR 65		
		South Jordan, UT 84095	RIO BLANCO COUNTY, CO 81648		
Permitted Feature:		Discharge:			
026 External Outfall		026-W ACUTE WET TESTING FOR 026A			
Report Dates & Status		DMR Due Date:		Status:	
Monitoring Period: From 01/01/21 to 03/31/21		04/28/21		Not DMR Validated	
Considerations for Form Completion					
SEE PART I A.2, PG 8-10, FOR DETAILS OF TEST PROCEDURE REPORT LC50- STATISTICAL POINT ESTIMATE WHICH IS LETHAL TO 50% OF TEST ORGANISMS, AND ATTACH ACUTE TOXICITY TEST REPORT FORM TO DMR					
Principal Executive Officer					
First Name:	Phillip	Title:		Telephone:	
Last Name:	Solomon	Vice-President Chief Engineer		801-619-6560	
No Data Indicator (NODI)					
Form NODI:	-				
Code	Parameter Name	Monitoring Location	Session #	Param. NODI	Sample Permit Req. Value NODI
TAM3C	LC50 Static Renewal 48Hr Acute Daphnia magna	1 - Effluent Gross	0	-	-
		Quantity or Loading	Qualifier 1 Value 1	Qualifier 2 Value 2	Qualifier 3 Value 3
		>=	100.0 MG AV MIN	23 - %	01/50 - Quarterly
		C - No Discharge	100.0 MG AV MIN	23 - %	GR - GRAB
TAN6C	LC50 Static 96Hr Acute Pimephales	1 - Effluent Gross	0	-	-
		Quantity or Loading	Qualifier 1 Value 1	Qualifier 2 Value 2	Qualifier 3 Value 3
		>=	100.0 MG AV MIN	23 - %	01/50 - Quarterly
		C - No Discharge	100.0 MG AV MIN	23 - %	GR - GRAB

Submission Note
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type

Edit Check Errors
 No errors.

Comments

Attachments
 No attachments

Report Last Saved By
 Blue Mountain Energy Inc
 User: kblunt@risatec.org
 Name: Kurtis Blunt
 E-Mail: kblunt@desarado.com
 Date/Time: 2021-04-15 10:57 (Time Zone: -06:00)

Report Last Signed By
 User: PSOLOMON1958
 Name: PHILLIP SOLOMON
 E-Mail: psolomon@desaradpower.com
 Date/Time: 2021-04-22 16:45 (Time Zone: -06:00)

DMR Copy of Record

Permit		Permittee:		Facility:				
Permit #: CO0038024		Blue Mountain Energy Inc		DESERADO MINE				
Major: No		10714 S Jordan Gateway Ste 300		3807 CR 65				
		South Jordan, UT 84095		RIO BLANCO COUNTY, CO 81648				
Permitted Feature:		Discharge:						
028 External Outfall		028-A		RFS SEDI POND TO RED WASH				
Report Dates & Status		DMR Due Date:		Status:				
Monitoring Period: From 01/01/21 to 03/31/21		04/28/21		Not DMR Validated				
TSS & TOTAL IRON LIMITS WILL BE WAIVED FOR 10YR 24HR PRECIP. EVENT - SEE (A.1, PG.3, FOR REQUIREMENTS OIL & GREASE REPORTING - (B.1.A, PG. 13, QTRLY SAMPLING INSTRUCTIONS - (C.7, PG. 14.								
Principal Executive Officer								
First Name:		Title:		Telephone:				
Philip Solomon		Vice-President Chief Engineer		801-619-6560				
Last Name:								
No Data Indicator (NOD)								
Form NOD:								
Code	Parameter Name	Monitoring Location	Season	Param. NOD	Sample Permit Req. Value NOD	Quantity or Loading Qualifier 1 Value 1 Qualifier 2 Value 2 Units	Quality or Concentration Qualifier 3 Value 3 Units	# of Ex. Frequency of Analysis Sample Type
00400	pH	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD	>= 6.5 MINIMUM C - No Discharge	<= 9.0 MAXIMUM C - No Discharge	12 SU 0230 - Twice Per Month GR - GRAB
00530	Solids, total suspended	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD	<= 35.0 300A AVG C - No Discharge	70.0 MX 7D AV C - No Discharge	19 - mg/L 0230 - Twice Per Month GR - GRAB
00545	Solids, settleable	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD	<= 0.5 DAILY MX C - No Discharge	25 - mL/L 0230 - Twice Per Month GR - GRAB	0230 - Twice Per Month GR - GRAB
01045	Iron, total [as Fe]	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD	<= 3.5 300A AVG C - No Discharge	7.0 DAILY MX C - No Discharge	19 - mg/L 0230 - Twice Per Month GR - GRAB
03582	Oil and grease	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD	<= 10.0 INST MAX C - No Discharge	19 - mg/L 7777 - Contingent GR - GRAB	0130 - Monthly IN - INSTAN
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD	Req Mon 300A AVG C - No Discharge	Req Mon DAILY MX 03 - MGD C - No Discharge	0130 - Monthly IN - INSTAN
70295	Solids, total dissolved	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD	Req Mon ORTR AVG C - No Discharge	Req Mon DAILY MX 19 - mg/L C - No Discharge	0130 - Quarterly GR - GRAB
84066	Oil and grease visual	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD	Req Mon INST MAX 9P - INST MAX C - No Discharge	0230 - Twice Per Month VI - VISUAL	0230 - Twice Per Month VI - VISUAL
Submission Note								
If a parameter row does not contain any values for the Sample not Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.								
Edit Check Errors								
No errors								
Comments								
Attachments								
No attachments.								
Report Last Saved By								
Blue Mountain Energy Inc								
User: kbunt@tristategi.org								
Name: Kurtis Blunt								
E-Mail: kbunt@deserado.com								
Date/Time: 2021-04-15 10:57 (Time Zone -06:00)								

Report Last Signed By

User:	PSOLOMON1958
Name:	PHILLIP SOLOMON
E-Mail:	psolomon@deseretpower.com
Date/Time:	2021-04-22 16:45 (Time Zone -06:00)

DMR Copy of Record

Permit Permit #: CO0038024 Major: No		Permittee: Blue Mountain Energy Inc 10714 S Jordan Gateway Ste 300 South Jordan, UT 84095		Facility: Facility Location: DESERADO MINE 3807 CR 85 RIO BLANCO COUNTY, CO 81648	
Permitted Feature: 029 External Outfall		Discharge: 029-A DISCHARGE TO RED WASH			
Report Dates & Status Monitoring Period: From 01/01/21 to 03/31/21 Considerations for Form Completion TSS & TOTAL IRON LIMITS WILL BE WAIVED FOR 10YR, 24HR PRECIP. EVENT - SEE I.A.1, PG. 3. FOR REQUIREMENTS OIL & GREASE REPORTING - I.B.1.A., PG. 13. QTRLY SAMPLING INSTRUCTIONS - I.C.7., PG. 14.		DMR Due Date: 04/28/21		Status: Not DMR Validated	
Principal Executive Officer First Name: Phillip Last Name: Solomon		Title: Vice-President Chief Engineer		Telephone: 801-619-8560	
No Data Indicator (NOD) Form NOD: -					

Code	Parameter Name	Monitoring Location	Season #	Permit NOD	Sample Permit Req. Value NOD	Quantity or Loading	Value 1	Qualifier 1	Units	Value 2	Qualifier 2	Value 3	Qualifier 3	Units	# of Ex.	Frequency of Analysis	Sample Type
00400	pH	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD		7.52	=		7.53	=			12 - SU	0	0230 - Twice Per Month	IS - INSTITU
							6.5 MINIMUM	>=						12 - SU	0	0230 - Twice Per Month	IS - INSTITU
00530	Solids, total suspended	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD			=	14.0					19 - mg/L	0	0230 - Twice Per Month	GR - GRAB
								<=	35.0 30DA AVG					19 - mg/L	0	0230 - Twice Per Month	GR - GRAB
00545	Solids, settleable	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD			<	0.1					25 - mL/L	0	0230 - Twice Per Month	GR - GRAB
								<=	0.5 DAILY MX					25 - mL/L	0	0230 - Twice Per Month	GR - GRAB
01045	Iron, total [as Fe]	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD			=	0.275					19 - mg/L	0	0230 - Twice Per Month	GR - GRAB
								<=	3.0 30DA AVG					19 - mg/L	0	0230 - Twice Per Month	GR - GRAB
03582	Oil and grease	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD									19 - mg/L		71/77 - Contingent	GR - GRAB
								<=	10.0 INST MAX								
									9 - Conditional Monitoring - Not Required This Period								
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD		0.025	=	0.043						0	95/99 - Continuous	IN - INSTAN
							Req Mon 30DA AVG	<=	0.61 DAILY MX							95/99 - Continuous	IN - INSTAN
70295	Solids, total dissolved	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD			=	2800.0					19 - mg/L	0	0190 - Quarterly	GR - GRAB
									Req Mon QTRTR AVG					19 - mg/L	0	0190 - Quarterly	GR - GRAB
84066	Oil and grease visual	1 - Effluent Gross	0	-	Sample Permit Req. Value NOD			=	9P - N=0, Y=1						0	0230 - Twice Per Month	VI - VISUAL
									9P - N=0, Y=1						0	0230 - Twice Per Month	VI - VISUAL

Submission Note
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
 No errors.

Comments

Attachments

No attachments.

Report Last Saved By

Blue Mountain Energy Inc

User:

kblunt@ristalegt.org

Name:

Kurtis Blunt

E-Mail:

kblunt@deserado.com

Date/Time:

2021-04-15 11:00 (Time Zone -06:00)

Report Last Signed By

User:

PSOLOMON1958

Name:

PHILLIP SOLOMON

E-Mail:

psolomon@deserelpower.com

Date/Time:

2021-04-22 18:45 (Time Zone -06:00)

DMR Copy of Record

Permit		Permittee:		Facility:	
Permit #:	CO0038024	Blue Mountain Energy Inc	DESERADO MINE		
Major:	No	10714 S Jordan Gateway Ste 300	3807 CR 65		
		South Jordan, UT 84095	RIO BLANCO COUNTY, CO 81648		
Permitted Feature:		Discharge:			
029- External Outfall		029-W ACUTE WET TESTING FOR 029A			
Report Dates & Status		DMR Due Date:		Status:	
Monitoring Period: From 01/01/21 to 03/31/21		04/28/21		Not DMR Validated	
Considerations for Form Completion					
SEE PART I.A.2, PG. 8-10, FOR DETAILS OF TEST PROCEDURE. REPORT LC50- STATISTICAL POINT ESTIMATE WHICH IS LETHAL TO 50% OF TEST ORGANISMS, AND ATTACH ACUTE TOXICITY TEST REPORT FORM TO DMR					
Principal Executive Officer					
First Name:	Phillip	Title:		Telephone:	
Last Name:	Solomon	Vice-President Chief Engineer		801-619-6560	
Form NODI:					
Code	Parameter Name	Monitoring Location	Season	Permit NODI	Sample Permit Req. Value NODI
TAM3C	LC50 Static Renewal 48Hr Acute Daphnia magna	1 - Effluent Gross	0	-	-
Quantity or Loading					
Qualifier 1 Value 1		Qualifier 2 Value 2	Qualifier 3 Value 3	Qualifier 4 Value 4	Qualifier 5 Value 5
100.0		100.0	100.0	100.0	100.0
23 - %		23 - %	23 - %	23 - %	23 - %
0		0	0	0	0
Frequency of Analysis Sample Type					
GR - GRAB		GR - GRAB		GR - GRAB	
Submission Note					
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type					
Edit Check Errors					
No errors					
Comments					
Attachments					
No attachments.					
Report Last Saved By					
Blue Mountain Energy Inc					
User:	kbunt@tristateleg.org				
Name:	Kurtis Blunt				
E-Mail:	kbunt@desoradio.com				
Date/Time:	2021-04-15 11:02 (Time Zone: -06:00)				
Report Last Signed By					
User:	PSOLOMON1958				
Name:	PHILLIP SOLOMON				
E-Mail:	psolomon@desorepower.com				
Date/Time:	2021-04-22 18:45 (Time Zone: -06:00)				

DMR Copy of Record

Permit		Permit #: CO0038024		Permittee: Blue Mountain Energy Inc		Facility: DESERADO MINE	
Major: No		Permittee Address: 10714 S Jordan Gateway Ste 300 South Jordan, UT 84095		Facility Location:		3607 CR 65 RIO BLANCO COUNTY, CO 81648	
Permitted Feature: 045 External Outfall		Discharge: 045-A SEWAGE TREATMENT PLANT					
Report Dates & Status		DMR Due Date: 04/28/21		Status: NetDMR Validated			
Monitoring Period: From 01/01/21 to 03/31/21							
INFLUENT SAMPLES MUST BE COLLECTED, ANALYZED & REPORTED MONTHLY REGARDLESS OF WHETHER AN EFFLUENT DISCHARGE OCCURS.							
Principal Executive Officer							
First Name: Phillip		Title: Vice-President Chief Engineer		Telephone: 901-619-6560			
Last Name: Solomon							
Form NODI: -							
Code	Parameter Name	Monitoring Location	Season of Permit NODI	Quantity or Loading	Qualifier 1	Qualifier 2	Qualifier 3
00310	BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	Value 1 14.79 Req Mon 30DA AVG	Value 2 14.79 Req Mon DAILY MX 26 - lbd	Value 3 307.6 Req Mon 30DA AVG	Value 4 19 - mgl Req Mon DAILY MX 19 - mgl
50050	Flow, In conduit or thru treatment plant	1 - Effluent Gross	0	Value 1 0.0058 Req Mon 30DA AVG <=	Value 2 0.0058 0.043 DAILY MX	Value 3 0.0058 0.043 DAILY MX	Value 4 0.0058 0.043 DAILY MX

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors

Comments

Attachments
No attachments.

Report Last Saved By
Blue Mountain Energy Inc

User: kblunt@insiategl.org
Name: Kurtis Blunt
E-Mail: kblunt@deserado.com
Date/Time: 2021-04-15 11:05 (Time Zone: -06:00)

Report Last Signed By

User: PSOLOMON1958
Name: PHILLIP SOLOMON
E-Mail: psolomon@deserapower.com
Date/Time: 2021-04-22 16:45 (Time Zone: -06:00)

DMR Copy of Record

Permit Permit #: CO0038024 Major: No		Permittee: Permittee Address: Blue Mountain Energy Inc 10714 S Jordan Gateway Ste 300 South Jordan, UT 84095 MNO-1 DP1 SEDI POND TO SCULLION GLCH		Facility: Facility Location: DESERADO MINE 3807 CR 85 RIO BLANCO COUNTY, CO 81648												
Permitted Feature: MNO External Outfall		Discharge:		Status: NetDMR Validated												
Report Dates & Status Monitoring Period: From 01/01/21 to 03/31/21 Considerations for Form Completion		DMR Due Date: 04/28/21		Telephone: 801-619-6560												
Principal Executive Officer First Name: Phillip Last Name: Solomon No Data Indicator (NODI)																
Form NODI:																
Code	Parameter Name	Monitoring Location	Season	Permit NODI	Quantity or Loading	Quality or Concentration	Value 1	Qualifier 1	Value 2	Qualifier 2	Value 3	Qualifier 3	Units	# of Ex.	Frequency of Analysis	Sample Type
00978	Arsenic, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	<		5.0		Req Mon DAILY MX	28 - ug/L	0	01590 - Quarterly	GR - GRA08	
00981	Selenium, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	<		5.0		Req Mon DAILY MX	28 - ug/L	0	01590 - Quarterly	GR - GRA08	
00998	Beryllium, total recoverable [as Be]	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	<		1.0		Req Mon DAILY MX	28 - ug/L	0	01590 - Quarterly	GR - GRA08	
01074	Nickel, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	<		5.0		Req Mon DAILY MX	28 - ug/L	0	01590 - Quarterly	GR - GRA08	
01094	Zinc, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	<		50.0		Req Mon DAILY MX	28 - ug/L	0	01590 - Quarterly	GR - GRA08	
01113	Cadmium, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	<		1.0		Req Mon DAILY MX	28 - ug/L	0	01590 - Quarterly	GR - GRA08	
01114	Lead, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	=		1.0		Req Mon DAILY MX	28 - ug/L	0	01590 - Quarterly	GR - GRA08	
01119	Copper, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	<		5.0		Req Mon DAILY MX	28 - ug/L	0	01590 - Quarterly	GR - GRA08	
04262	Chromium, trivalent total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	=		2.0		Req Mon DAILY MX	28 - ug/L	0	01590 - Quarterly	GR - GRA08	
11123	Manganese, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	=		24.0		Req Mon DAILY MX	28 - ug/L	0	01590 - Quarterly	GR - GRA08	

Submission Note
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
 No errors.

Comments

Attachments
 No attachments.

Report Last Saved By
Blue Mountain Energy, Inc

User: kbunt@hiscategi.org

Name: Kurtis Blunt

E-Mail: kbunt@deserado.com

Date/Time: 2021-04-15 11:09 (Time Zone -06:00)

Report Last Signed By

User: PSOLOMON1958

Name: PHILLIP SOLOMON

E-Mail: psolomon@deseretpower.com

Date/Time: 2021-04-22 16:45 (Time Zone -06:00)

DMR Copy of Record

Permit Permit #: CO0038024 Major: No Permitted Feature: MNO External Outfall Report Dates & Status: From 01/01/21 to 03/31/21 Monitoring Period: Considerations for Form Completion Principal Executive Officer: Phillip Solomon First Name: Phillip Last Name: Solomon No Data Indicator (NODI): Form NODI:		Permittee: Blue Mountain Energy Inc Permittee Address: 10714 S Jordan Gateway Ste 300 South Jordan, UT 84095 Discharge: MNO-4 PP2 TO SCULLION GULCH DMR Due Date: 04/28/21 Status: Not DMR Validated Title: Vice-President Chief Engineer Telephone: 801-519-6560		Facility: DESERADO MINE Facility Location: 3607 CR 65 RIO BLANCO COUNTY, CO 81648	
---	--	--	--	---	--

Code	Parameter Name	Monitoring Location	Season	Param. NODI	Quantity or Loading		Quality or Concentration		# of Ex.	Frequency of Analysis	Sample Type
					Qualifier 1 Value 1	Qualifier 2 Value 2	Qualifier 3 Value 3	Qualifier 4 Value 4			
00978	Arsenic, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB	
00981	Selenium, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB	
00998	Beryllium, total recoverable (as Be)	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB	
01074	Nickel, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB	
01094	Zinc, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB	
01113	Cadmium, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB	
01114	Lead, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB	
01119	Copper, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB	
04282	Chromium, trivalent total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB	
11123	Manganese, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB	

Submission Note
 If a parameter row does not contain any values for the Sample not Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
 No errors.

Comments

Attachments
 No attachments.

Report Last Saved By
Blue Mountain Energy, Inc

User: kblunt@tristategl.org
Name: Kurtis Blunt
E-Mail: kblunt@deserado.com
Date/Time: 2021-04-15 11:10 (Time Zone -06:00)

Report Last Signed By

User: PSOLOMON1958
Name: PHILLIP SOLOMON
E-Mail: psolomon@deseretpower.com
Date/Time: 2021-04-22 16:45 (Time Zone -06:00)

DMR Copy of Record

Permit		Permit #: CO0038024		Permittee: Blue Mountain Energy Inc		Facility: DESERADO MINE	
Major:		No		10714 S Jordan Gateway Site 300 South Jordan, UT 84095		Facility Location: 3807 CR 65 RIO BLANCO COUNTY, CO 81648	
Permitted Feature:		MND External Outfall		Discharge: MND-B SS-1 SLOT STORAGE TO RED WASH			
Report Dates & Status							
Monitoring Period: From 01/01/21 to 03/31/21				DMR Due Date: 04/28/21		Status: NeDMR Validated	
Considerations for Form Completion							
Principal Executive Officer				Title: Vice-President Chief Engineer		Telephone: 801-819-6560	
First Name: Phillip							
Last Name: Solomon							
No Data Indicator (NODI)							
Form NODI:							

Code	Parameter Name	Monitoring Location	Season	Param. NODI	Quantity or Loading		Quality or Concentration		Units	# of Ex.	Frequency of Analysis	Sample Type
					Qualifier 1	Value 1	Qualifier 2	Value 2				
00978	Arsenic, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI		Req Mon 300A AVG	C - No Discharge	28 - ug/L		01/90 - Quarterly	GR - GRAB
00981	Selenium, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI		Req Mon 300A AVG	C - No Discharge	28 - ug/L		01/90 - Quarterly	GR - GRAB
00998	Beryllium, total recoverable [as Be]	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI		Req Mon 300A AVG	C - No Discharge	28 - ug/L		01/90 - Quarterly	GR - GRAB
01074	Nickel, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI		Req Mon 300A AVG	C - No Discharge	28 - ug/L		01/90 - Quarterly	GR - GRAB
01094	Zinc, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI		Req Mon 300A AVG	C - No Discharge	28 - ug/L		01/90 - Quarterly	GR - GRAB
01113	Cadmium, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI		Req Mon 300A AVG	C - No Discharge	28 - ug/L		01/90 - Quarterly	GR - GRAB
01114	Lead, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI		Req Mon 300A AVG	C - No Discharge	28 - ug/L		01/90 - Quarterly	GR - GRAB
01119	Copper, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI		Req Mon 300A AVG	C - No Discharge	28 - ug/L		01/90 - Quarterly	GR - GRAB
04262	Chromium, trivalent total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI		Req Mon 300A AVG	C - No Discharge	28 - ug/L		01/90 - Quarterly	GR - GRAB
11123	Manganese, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI		Req Mon 300A AVG	C - No Discharge	28 - ug/L		01/90 - Quarterly	GR - GRAB

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors

Comments

Attachments
No attachments.

Report Last Saved By

Blue Mountain Energy Inc

User:

kblunt@hisiateg.org

Name:

Kurtis Blunt

E-Mail:

kblunt@deseruido.com

Date/Time:

2021-04-15 11:11 (Time Zone -08:00)

Report Last Signed By

User:

PSOLOMON1958

Name:

PHILLIP SOLOMON

E-Mail:

psolomon@deseretpower.com

Date/Time:

2021-04-22 16:45 (Time Zone -08:00)

DMR Copy of Record

Permit		Permit #: CO0038024		Facility: DESERADO MINE	
Major: No		Permittee: Blue Mountain Energy Inc		Facility Location: 3807 CR 85 RIO BLANCO COUNTY, CO 81648	
Permitted Feature: MNU External Outfall		Discharge: MNU-9 SS-2 SLOT STORAGE TO RED WASH			
Report Dates & Status		DMR Due Date: 04/28/21		Status: NetDMR Validated	
Monitoring Period: From 01/01/21 to 03/31/21					
Considerations for Form Completion					
Principal Executive Officer		Title:		Telephone: 801-619-5580	
First Name: Phillip					
Last Name: Solomon					
No Data Indicator (NODI)					
Form NODI:					

Code	Parameter Name	Monitoring Location	Season	Param. NODI	Quantity or Loading			Quality or Concentration			Units	# of Ex. Frequency of Analysis	Sample Type
					Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3			
00978	Arsenic, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI			Req Mon 300A AVG		Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB
								C - No Discharge					
00981	Selenium, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI			Req Mon 300A AVG		Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB
								C - No Discharge					
00998	Beryllium, total recoverable [as Be]	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI			Req Mon 300A AVG		Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB
								C - No Discharge					
01074	Nickel, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI			Req Mon 300A AVG		Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB
								C - No Discharge					
01094	Zinc, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI			Req Mon 300A AVG		Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB
								C - No Discharge					
01113	Cadmium, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI			Req Mon 300A AVG		Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB
								C - No Discharge					
01114	Lead, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI			Req Mon 300A AVG		Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB
								C - No Discharge					
01119	Copper, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI			Req Mon 300A AVG		Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB
								C - No Discharge					
04262	Chromium, trivalent total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI			Req Mon 300A AVG		Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB
								C - No Discharge					
11123	Manganese, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI			Req Mon 300A AVG		Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	GR - GRAB
								C - No Discharge					

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments
No attachments.

Report Last Saved By
Blue Mountain Energy Inc

User:	kblum@tristatag.org
Name:	Kurtis Blum
E-Mail:	kblum@deseretpower.com
Date/Time:	2021-04-15 11:11 (Time Zone -08:00)
Report Last Signed By	
User:	PSOLOMON1958
Name:	PHILLIP SOLOMON
E-Mail:	psolomon@deseretpower.com
Date/Time:	2021-04-22 16:45 (Time Zone -06:00)

DMR Copy of Record

Permit Permit #: CO0038024 Major: No		Permittee: Blue Mountain Energy Inc 10714 S Jordan Gateway Ste 300 South Jordan, UT 84095		Facility: DESERADO MINE 3807 CR 65 RIO BLANCO COUNTY, CO 81648	
Permitted Feature: MN2 External Outfall		Discharge: MN2-5 SDH35 SEDI POND TO RED WASH			
Report Dates & Status Monitoring Period: From 01/01/21 to 03/31/21 Considerations for Form Completion		DMR Due Date: 04/28/21		Status: NetDMR Validated	
Principal Executive Officer First Name: Phillip Last Name: Solomon		Title: Vice-President Chief Engineer		Telephone: 801-619-8560	
No Data Indicator (NODI) Form NODI: -					

Code	Parameter Name	Monitoring Location	Season	# Param. NODI	Quantity or Loading		Quality or Concentration		# of Ex.	Frequency of Analysis	Sample Type
					Qualifier 1 Value 1	Qualifier 2 Value 2	Qualifier 3 Value 3	Qualifier 4 Value 4			
00978	Arsenic, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MAX	28 - ug/L	01/90 - Quarterly	GR - GRAB	
00981	Selenium, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MAX	28 - ug/L	01/90 - Quarterly	GR - GRAB	
00998	Beryllium, total recoverable (as Be)	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MAX	28 - ug/L	01/90 - Quarterly	GR - GRAB	
01074	Nickel, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MAX	28 - ug/L	01/90 - Quarterly	GR - GRAB	
01094	Zinc, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MAX	28 - ug/L	01/90 - Quarterly	GR - GRAB	
01113	Cadmium, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MAX	28 - ug/L	01/90 - Quarterly	GR - GRAB	
01114	Lead, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MAX	28 - ug/L	01/90 - Quarterly	GR - GRAB	
01119	Copper, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MAX	28 - ug/L	01/90 - Quarterly	GR - GRAB	
04262	Chromium, trivalent total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MAX	28 - ug/L	01/90 - Quarterly	GR - GRAB	
11123	Manganese, total recoverable	1 - Effluent Gross	0	-	Sample Permit Req. Value NODI	Req Mon 300A AVG	Req Mon DAILY MAX	28 - ug/L	01/90 - Quarterly	GR - GRAB	

Submission Note
 If a parameter row does not contain any values for the Sample or Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
 No errors.

Comments

Attachments
 No attachments.

Report Last Saved By
Blue Mountain Energy, Inc

User: kblunt@hristatlogi.org
Name: Kurtis Blunt
E-Mail: kblunt@deserado.com
Date/Time: 2021-04-15 11:15 (Time Zone: -06:00)

Report Last Signed By

User: PSOLOMON1958
Name: PHILLIP SOLOMON
E-Mail: psolomon@deseretpower.com
Date/Time: 2021-04-23 08:42 (Time Zone: -06:00)

DMR Copy of Record

Permit		Permittee:		Facility:		
Permit #:	CO0038024	Blue Mountain Energy Inc		DESERADO MINE		
Major:	No	10714 S Jordan Gateway Ste 300 South Jordan, UT 84095		3807 CR 65 RIO BLANCO COUNTY, CO 81048		
Permitted Feature:		Discharge:				
MN2 External Outfall		MN2-9 DISCHARGE TO RED WASH				
Report Dates & Status		DMR Due Date:		Status:		
Monitoring Period: From 01/01/21 to 03/31/21 Considerations for Form Completion		04/28/21		NetDMR Validated		
Principal Executive Officer		Title:		Telephone:		
First Name: Last Name: No Data Indicator (NODI) Form NODI:		Vice-President Chief Engineer		801-619-5550		
Paramater Name		Monitoring Location Season # Param. NODI		# of Ex. Frequency of Analysis Sample Type		
Code	Paramater Name	Monitoring Location	Season #	Param. NODI		
00978	Arsenic, total recoverable	1 - Effluent Gross	0	-		
					Sample Permit Req. Value NODI	
					Qualifier 1 Value 1	Qualifier 2 Value 2
					Qualifier 3 Value 3	Units
					5.0	28 - ug/L
					Req Mon 300A AVG	01500 - Quarterly
					Req Mon DAILY MX 28 - ug/L	01500 - Quarterly
						GR - GRAB
00981	Selenium, total recoverable	1 - Effluent Gross	0	-		
					Sample Permit Req. Value NODI	
					Qualifier 1 Value 1	Qualifier 2 Value 2
					Qualifier 3 Value 3	Units
					5.0	28 - ug/L
					Req Mon 300A AVG	01500 - Quarterly
					Req Mon DAILY MX 28 - ug/L	01500 - Quarterly
						GR - GRAB
00998	Beryllium, total recoverable (as Be)	1 - Effluent Gross	0	-		
					Sample Permit Req. Value NODI	
					Qualifier 1 Value 1	Qualifier 2 Value 2
					Qualifier 3 Value 3	Units
					1.0	28 - ug/L
					Req Mon 300A AVG	01500 - Quarterly
					Req Mon DAILY MX 28 - ug/L	01500 - Quarterly
						GR - GRAB
01074	Nickel, total recoverable	1 - Effluent Gross	0	-		
					Sample Permit Req. Value NODI	
					Qualifier 1 Value 1	Qualifier 2 Value 2
					Qualifier 3 Value 3	Units
					94.0	28 - ug/L
					Req Mon 300A AVG	01500 - Quarterly
					Req Mon DAILY MX 28 - ug/L	01500 - Quarterly
						GR - GRAB
01094	Zinc, total recoverable	1 - Effluent Gross	0	-		
					Sample Permit Req. Value NODI	
					Qualifier 1 Value 1	Qualifier 2 Value 2
					Qualifier 3 Value 3	Units
					50.0	28 - ug/L
					Req Mon 300A AVG	01500 - Quarterly
					Req Mon DAILY MX 28 - ug/L	01500 - Quarterly
						GR - GRAB
01113	Cadmium, total recoverable	1 - Effluent Gross	0	-		
					Sample Permit Req. Value NODI	
					Qualifier 1 Value 1	Qualifier 2 Value 2
					Qualifier 3 Value 3	Units
					1.0	28 - ug/L
					Req Mon 300A AVG	01500 - Quarterly
					Req Mon DAILY MX 28 - ug/L	01500 - Quarterly
						GR - GRAB
01114	Lead, total recoverable	1 - Effluent Gross	0	-		
					Sample Permit Req. Value NODI	
					Qualifier 1 Value 1	Qualifier 2 Value 2
					Qualifier 3 Value 3	Units
					3.0	28 - ug/L
					Req Mon 300A AVG	01500 - Quarterly
					Req Mon DAILY MX 28 - ug/L	01500 - Quarterly
						GR - GRAB
01119	Copper, total recoverable	1 - Effluent Gross	0	-		
					Sample Permit Req. Value NODI	
					Qualifier 1 Value 1	Qualifier 2 Value 2
					Qualifier 3 Value 3	Units
					6.0	28 - ug/L
					Req Mon 300A AVG	01500 - Quarterly
					Req Mon DAILY MX 28 - ug/L	01500 - Quarterly
						GR - GRAB
04282	Chromium, trivalent total recoverable	1 - Effluent Gross	0	-		
					Sample Permit Req. Value NODI	
					Qualifier 1 Value 1	Qualifier 2 Value 2
					Qualifier 3 Value 3	Units
					1.0	28 - ug/L
					Req Mon 300A AVG	01500 - Quarterly
					Req Mon DAILY MX 28 - ug/L	01500 - Quarterly
						GR - GRAB
11123	Manganese, total recoverable	1 - Effluent Gross	0	-		
					Sample Permit Req. Value NODI	
					Qualifier 1 Value 1	Qualifier 2 Value 2
					Qualifier 3 Value 3	Units
					10.0	28 - ug/L
					Req Mon 300A AVG	01500 - Quarterly
					Req Mon DAILY MX 28 - ug/L	01500 - Quarterly
						GR - GRAB

Submission Note
If a parameter row does not contain any values for the Sample not Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors

Comments

Attachments

No attachments

Report Last Saved By
Blue Mountain Energy, Inc

User: kbunt@hislategt.org

Name: Kurtis Blunt

E-Mail: kbunt@deserado.com

Date/Time: 2021-04-15 11:21 (Time Zone -08:00)

Report Last Signed By

User: PSOLOMON1958

Name: PHILLIP SOLOMON

E-Mail: psolomon@deserapower.com

Date/Time: 2021-04-23 08:42 (Time Zone -08:00)