



## Seneca Coal Company

---

July 9, 2021

Robin Reilly  
Colorado Division of Reclamation, Mining and Safety  
1313 Sherman Street, Room 215  
Denver, CO 80203

**RE: Seneca II W Mine, Permit C-82-057, Second Quarter 2021 IIR**

Dear Robin:

In accordance with Rule 4.05.9(17), please find enclosed the Seneca II West Mine (SIIW) Impoundment Inspection Report (IIR) and Impoundment Inspection Log (IIL). Please contact me with any comments and/or questions.

Sincerely,

Miranda Kawcak  
Environmental Manager  
Peabody, Colorado Operations

Enclosure: SIIW IIR

<b>Mining Area</b> <b>Date Inspected</b> <b>Impoundment</b> <b>NPDES ID No</b> <b>Owner's Rep</b>	Seneca II West Mine	<b>Facility Configuration</b> <b>Date Last Inspected</b> <b>Pond Location</b> <b>Site Location</b> <b>Inspector</b>	Cross-Vally Pond	<b>Quarterly Impoundment Inspection Form</b>
	6/14/2021		3/22/2021	
	Pond #005		NW¼ SW¼, Sec. 10, T5N, R88W	
	CMLRD Permit No. C-82-057		8 mi. S of Hayden, CO	
	Miranda Kawcak		Jason Herden	
<b>Mark or Write in Appropriate Response:</b>				
FEATURE		PROBLEM		COMMENTS
		YES (Above)	NO (Below)	
<b>GENERAL</b>				
Water Level (above or below principal spillway)			X	1.5 FT BELOW
Existing Embankment Freeboard (7.4 ft)		8.4		
Outflow (gpm)			X	0 GPM
<b>EROSION</b>				
Rills & Gullies on Embankment			X	
Wave Erosion			X	
Spillway Erosion			X	
Burrows			x	
Other			X	
<b>STRUCTURAL</b>				
Differential Settling			X	
Cracks or Slides			X	
Seepage			X	
Other			X	
<b>STRUCTURES</b>				
Principal Spillway				
Clogged Orifice			X	
Clogged or Damaged Culvert			X	
Damaged Headgate			NA	
Emergency Spillway				
Erosion			X	
Riprap			X	
Clogged or Damaged Culvert			X	
Other			X	
<b>MAINTENACE</b>				
Maintenance Required			X	SPRING AT DAM (NO IMPACT)
Maintenance Performed			X	
Additional Comments		X		

<b>Mining Area</b>	Seneca II West Mine	<b>Facility Configuration</b>	Cross-Vally Pond	<b>Quarterly Impoundment Inspection Form</b>
<b>Date Inspected</b>	6/14/2021	<b>Date Last Inspected</b>	3/22/2021	
<b>Impoundment</b>	Pond #006	<b>Pond Location</b>	NW¼ NW¼, Sec. 22, T5N, R88W	
<b>NPDES ID No</b>	CO-0000221 D.P. 006	<b>Site Location</b>	8 mi. S of Hayden, CO	
<b>Owner's Rep</b>	Miranda Kawcak	<b>Inspector</b>	Jason Herden	
<b>Mark or Write in Appropriate Response:</b>				
<b>FEATURE</b>	<b>PROBLEM</b>		<b>COMMENTS</b>	
	<b>YES (Above)</b>	<b>NO (Below)</b>		
<b>GENERAL</b>				
Water Level (above or below principal spillway)	X		0.1 FT ABOVE	
Existing Embankment Freeboard (7.5 ft)	7.5			
Outflow (gpm)	X		42.1 GPM	
<b>EROSION</b>				
Rills & Gullies on Embankment		X		
Wave Erosion		X		
Spillway Erosion		X		
Burrows		X		
Other		X		
<b>STRUCTURAL</b>				
Differential Settling		X		
Cracks or Slides		X		
Seepage		X		
Other		X		
<b>STRUCTURES</b>				
<b>Principal Spillway</b>				
Clogged Orifice		X		
Clogged or Damaged Culvert		X		
Damaged Headgate		NA		
<b>Emergency Spillway</b>				
Erosion		X		
Riprap		X		
Clogged or Damaged Culvert		X		
Other		X		
<b>MAINTENACE</b>				
Maintenance Required		X	SLUFF ON SOUTH SIDE (NO IMPACT)	
Maintenance Performed		X		
Additional Comments	X			

<b>Mining Area</b> <b>Date Inspected</b> <b>Impoundment</b> <b>NPDES ID No</b> <b>Owner's Rep</b>	Seneca II West Mine	<b>Facility Configuration</b> <b>Date Last Inspected</b> <b>Pond Location</b> <b>Site Location</b> <b>Inspector</b>	Cross-Vally Pond	<b>Quarterly Impoundment Inspection Form</b>
	6/14/2021		3/22/2021	
	Pond #009		SE¼ SW¼, Sec. 11, T5N, R88W	
	CO-0000221 D.P. 009		8 mi. S of Hayden, CO	
	Miranda Kawcak		Jason Herden	
<b>Mark or Write in Appropriate Response:</b>				
FEATURE		PROBLEM		COMMENTS
		YES (Above)	NO (Below)	
<b>GENERAL</b>				
Water Level (above or below principal spillway)			X	2.5 FT BELOW
Existing Embankment Freeboard (6.9 ft)		7.4		
Outflow (gpm)			X	0 GPM
<b>EROSION</b>				
Rills & Gullies on Embankment			X	
Wave Erosion			X	
Spillway Erosion			X	
Burrows			X	
Other			X	
<b>STRUCTURAL</b>				
Differential Settling			X	
Cracks or Slides			X	
Seepage			X	
Other			X	
<b>STRUCTURES</b>				
Principal Spillway				
Clogged Orifice			X	
Clogged or Damaged Culvert			X	
Damaged Headgate			NA	
Emergency Spillway				
Erosion			X	
Riprap			X	
Clogged or Damaged Culvert			X	
Other			X	
<b>MAINTENACE</b>				
Maintenance Required			X	
Maintenance Performed			X	
Additional Comments			X	

<b>Mining Area</b> <b>Date Inspected</b> <b>Impoundment</b> <b>NPDES ID No</b> <b>Owner's Rep</b>	Seneca II West Mine	<b>Facility Configuration</b> <b>Date Last Inspected</b> <b>Pond Location</b> <b>Site Location</b> <b>Inspector</b>	Cross-Vally Pond	<b>Quarterly Impoundment Inspection Form</b>
	6/14/2021		3/22/2021	
	Pond #015		NE¼ SE¼, Sec. 23, T5N, R88W	
	CO-0000221 D.P. 015		8 mi. S of Hayden, CO	
	Miranda Kawcak		Jason Herden	
<b>Mark or Write in Appropriate Response:</b>				
FEATURE		PROBLEM		COMMENTS
		YES (Above)	NO (Below)	
<b>GENERAL</b>				
Water Level (above or below principal spillway)		X		0.3 FT BELOW
Existing Embankment Freeboard (4.0 ft)		4.0		
Outflow (gpm)		X		0 GPM
<b>EROSION</b>				
Rills & Gullies on Embankment			X	
Wave Erosion			X	
Spillway Erosion			X	
Burrows			X	
Other			X	
<b>STRUCTURAL</b>				
Differential Settling			X	
Cracks or Slides			X	
Seepage			X	
Other			X	
<b>STRUCTURES</b>				
Principal Spillway				
Clogged Orifice			X	
Clogged or Damaged Culvert			X	
Damaged Headgate			NA	
Emergency Spillway				
Erosion			X	
Riprap			X	
Clogged or Damaged Culvert			X	
Other			X	
<b>MAINTENANCE</b>				
Maintenance Required			X	
Maintenance Performed			X	
Additional Comments			X	

<b>Mining Area</b> <b>Date Inspected</b> <b>Impoundment</b> <b>NPDES ID No</b> <b>Owner's Rep</b>	Seneca II West Mine	<b>Facility Configuration</b> <b>Date Last Inspected</b> <b>Pond Location</b> <b>Site Location</b> <b>Inspector</b>	Cross-Vally Pond	<b>Quarterly Impoundment Inspection Form</b>
	6/14/2021		3/22/2021	
	Pond #016		NE¼ SE¼, Sec. 27, T5N, R88W	
	CO-0000221 D.P. 016		8 mi. S of Hayden, CO	
	Miranda Kawcak		Jason Herden	
<b>Mark or Write in Appropriate Response:</b>				
<b>FEATURE</b>		<b>PROBLEM</b>		<b>COMMENTS</b>
		<b>YES (Above)</b>	<b>NO (Below)</b>	
<b>GENERAL</b>				
Water Level (above or below principal spillway)		X		0.1 FT ABOVE
Existing Embankment Freeboard (6.8 ft)		6.8		
Outflow (gpm)		X		63.4 GPM
<b>EROSION</b>				
Rills & Gullies on Embankment			X	
Wave Erosion			X	
Spillway Erosion			X	
Burrows			X	
Other			X	
<b>STRUCTURAL</b>				
Differential Settling			X	
Cracks or Slides			X	
Seepage			X	
Other			X	
<b>STRUCTURES</b>				
Principal Spillway				
Clogged Orifice			X	
Clogged or Damaged Culvert			X	
Damaged Headgate			NA	
Emergency Spillway				
Erosion			X	
Riprap			X	
Clogged or Damaged Culvert			X	
Other			X	
<b>MAINTENACE</b>				
Maintenance Required		X		SMALL SEEP
Maintenance Performed			X	
Additional Comments		X		

<b>Mining Area</b>	Seneca II West Mine	<b>Facility Configuration</b>	Cross-Vally Pond	<b>Quarterly Impoundment Inspection Form</b>
<b>Date Inspected</b>	6/14/2021	<b>Date Last Inspected</b>	3/22/2021	
<b>Impoundment</b>	Pond #017	<b>Pond Location</b>	SW¼ NE¼, Sec. 34, T5N, R88W	
<b>NPDES ID No</b>	CO-0000221 D.P. 017	<b>Site Location</b>	8 mi. S of Hayden, CO	
<b>Owner's Rep</b>	Miranda Kawcak	<b>Inspector</b>	Jason Herden	
<b>Mark or Write in Appropriate Response:</b>				
<b>FEATURE</b>	<b>PROBLEM</b>		<b>COMMENTS</b>	
	<b>YES (Above)</b>	<b>NO (Below)</b>		
<b>GENERAL</b>				
Water Level (above or below principal spillway)	X		0.1 FT ABOVE	
Existing Embankment Freeboard (3.1 ft)	3.1			
Outflow (gpm)	X		1 GPM	
<b>EROSION</b>				
Rills & Gullies on Embankment		X		
Wave Erosion		X		
Spillway Erosion		X		
Burrows		X		
Other		X		
<b>STRUCTURAL</b>				
Differential Settling		X		
Cracks or Slides		X		
Seepage		X		
Other		X		
<b>STRUCTURES</b>				
<b>Principal Spillway</b>				
Clogged Orifice		X		
Clogged or Damaged Culvert		X		
Damaged Headgate		NA		
<b>Emergency Spillway</b>				
Erosion		X		
Riprap		X		
Clogged or Damaged Culvert		X		
Other		X		
<b>MAINTENACE</b>				
Maintenance Required		X		
Maintenance Performed		X		
Additional Comments		X		

<b>Mining Area</b> <b>Date Inspected</b> <b>Impoundment</b> <b>NPDES ID No</b> <b>Owner's Rep</b>	Seneca II West Mine	<b>Facility Configuration</b> <b>Date Last Inspected</b> <b>Pond Location</b> <b>Site Location</b> <b>Inspector</b>	Stockpond	<b>Quarterly Impoundment Inspection Form</b>
	6/17/2021		3/22/2021	
	Stock Tank T-2		NW¼SW¼, Sec 22, T5N, R88W	
	N/A		8 mi S of Hayden, CO	
	Miranda Kawcak		Jason Herden	
<b>Mark or Write in Appropriate Response:</b>				
FEATURE		PROBLEM		COMMENTS
		YES (Above)	NO (Below)	
<b>GENERAL</b>				
Water Level (above or below principal spillway)			X	0 GPM
<b>EROSION</b>				
Rills & Gullies on Embankment			X	
Wave Erosion			X	
Spillway Erosion			X	
Burrows			X	
Other			X	
<b>STRUCTURAL</b>				
Differential Settling			X	
Cracks or Slides			X	
Seepage			X	
Other			X	
<b>STRUCTURES</b>				
Principal Spillway				
Clogged Orifice			NA	
Clogged or Damaged Culvert			NA	
Damaged Headgate			NA	
Emergency Spillway				
Erosion			X	
Riprap			X	
Clogged or Damaged Culvert			NA	
Other			X	
<b>MAINTENACE</b>				
Maintenance Required			X	
Maintenance Performed			X	
Additional Comments			X	



Mining Area Date Inspected Impoundment NPDES ID No Owner's Rep	Seneca II West Mine	Facility Configuration Date Last Inspected Pond Location Site Location Inspector	Stockpond	Quarterly Impoundment Inspection Form
	6/17/2021		3/22/2021	
	Stock Tank T-3		NW¼SE¼, Sec 22, T5N, R88W	
	N/A		8 mi S of Hayden, CO	
	Miranda Kawcak		Jason Herden	
Mark or Write in Appropriate Response:				
FEATURE	PROBLEM		COMMENTS	
	YES (Above)	NO (Below)		
GENERAL				
Water Level (above or below principal spillway)		X	3.1 FT BELOW	
EROSION				
Rills & Gullies on Embankment		X		
Wave Erosion		X		
Spillway Erosion		X		
Burrows		X		
Other		X		
STRUCTURAL				
Differential Settling		X		
Cracks or Slides		X		
Seepage		X		
Other		X		
STRUCTURES				
Principal Spillway				
Clogged Orifice		NA		
Clogged or Damaged Culvert		NA		
Damaged Headgate		NA		
Emergency Spillway				
Erosion		X		
Riprap		X		
Clogged or Damaged Culvert		NA		
Other		X		
MAINTENACE				
Maintenance Required		X		
Maintenance Performed		X		
Additional Comments		X		

<b>Mining Area</b>	Seneca II West Mine	<b>Facility Configuration</b>	Stockpond	<b>Quarterly Impoundment Inspection Form</b>
<b>Date Inspected</b>	6/17/2021	<b>Date Last Inspected</b>	3/22/2021	
<b>Impoundment</b>	Stock Tank T-5	<b>Pond Location</b>	NE¼ Sec 22, T5N, R88W	
<b>NPDES ID No</b>	N/A	<b>Site Location</b>	8 mi S of Hayden, CO	
<b>Owner's Rep</b>	Miranda Kawcak	<b>Inspector</b>	Jason Herden	
<b>Mark or Write in Appropriate Response:</b>				
<b>FEATURE</b>	<b>PROBLEM</b>		<b>COMMENTS</b>	
	<b>YES (Above)</b>	<b>NO (Below)</b>		
<b>GENERAL</b>				
Water Level (above or below principal spillway)		X	3.3 FT BELOW	
<b>EROSION</b>				
Rills & Gullies on Embankment		X		
Wave Erosion		X		
Spillway Erosion		X		
Burrows		X		
Other		X		
<b>STRUCTURAL</b>				
Differential Settling		X		
Cracks or Slides		X		
Seepage		X		
Other		X		
<b>STRUCTURES</b>				
Principal Spillway				
Clogged Orifice		NA		
Clogged or Damaged Culvert		NA		
Damaged Headgate		NA		
Emergency Spillway				
Erosion		X		
Riprap		X		
Clogged or Damaged Culvert		NA		
Other		X		
<b>MAINTENACE</b>				
Maintenance Required		X		
Maintenance Performed		X		
Additional Comments		X		

Mining Area Date Inspected Impoundment NPDES ID No Owner's Rep	Seneca II West Mine	Facility Configuration Date Last Inspected Pond Location Site Location Inspector	Stockpond	Quarterly Impoundment Inspection Form
	6/17/2021		3/22/2021	
	Stock Tank T-18		NW¼NE¼, Sec 15, T5N, R88W	
	N/A		8 mi S of Hayden, CO	
	Miranda Kawcak		Jason Herden	
Mark or Write in Appropriate Response:				
FEATURE	PROBLEM		COMMENTS	
	YES (Above)	NO (Below)		
GENERAL				
Water Level (above or below principal spillway)		X	2.3 FT BELOW	
EROSION				
Rills & Gullies on Embankment		X		
Wave Erosion		X		
Spillway Erosion		X		
Burrows		X		
Other		X		
STRUCTURAL				
Differential Settling		X		
Cracks or Slides		X		
Seepage		X		
Other		X		
STRUCTURES				
Principal Spillway				
Clogged Orifice		NA		
Clogged or Damaged Culvert		NA		
Damaged Headgate		NA		
Emergency Spillway				
Erosion		X		
Riprap		X		
Clogged or Damaged Culvert		NA		
Other		X		
MAINTENANCE				
Maintenance Required		X		
Maintenance Performed		X		
Additional Comments		X		

<b>Mining Area</b> <b>Date Inspected</b> <b>Impoundment</b> <b>NPDES ID No</b> <b>Owner's Rep</b>	Seneca II West Mine	<b>Facility Configuration</b> <b>Date Last Inspected</b> <b>Pond Location</b> <b>Site Location</b> <b>Inspector</b>	Stockpond	<b>Quarterly Impoundment Inspection Form</b>
	6/17/2021		3/22/2021	
	Stock Tank T-20		NW¼NE¼, Sec 15, T5N, R88W	
	N/A		8 mi S of Hayden, CO	
	Miranda Kawcak		Jason Herden	
<b>Mark or Write in Appropriate Response:</b>				
FEATURE		PROBLEM		COMMENTS
		YES (Above)	NO (Below)	
<b>GENERAL</b>				
Water Level (above or below principal spillway)			X	3.4 FT BELOW
<b>EROSION</b>				
Rills & Gullies on Embankment			X	
Wave Erosion			X	
Spillway Erosion			X	
Burrows			X	
Other			X	
<b>STRUCTURAL</b>				
Differential Settling			X	
Cracks or Slides			X	
Seepage			X	
Other			X	
<b>STRUCTURES</b>				
Principal Spillway				
Clogged Orifice			NA	
Clogged or Damaged Culvert			NA	
Damaged Headgate			NA	
Emergency Spillway				
Erosion			X	
Riprap			X	
Clogged or Damaged Culvert			NA	
Other			X	
<b>MAINTENANCE</b>				
Maintenance Required			X	
Maintenance Performed			X	
Additional Comments			X	

<b>Mining Area</b> <b>Date Inspected</b> <b>Impoundment</b> <b>NPDES ID No</b> <b>Owner's Rep</b>	Seneca II West Mine	<b>Facility Configuration</b> <b>Date Last Inspected</b> <b>Pond Location</b> <b>Site Location</b> <b>Inspector</b>	Stockpond	<b>Quarterly Impoundment Inspection Form</b>
	6/17/2021		3/22/2021	
	Stock Tank T-22		SE¼SW¼, Sec 10, T5N, R88W	
	N/A		8 mi S of Hayden, CO	
	Miranda Kawcak		Jason Herden	
<b>Mark or Write in Appropriate Response:</b>				
FEATURE		PROBLEM		COMMENTS
		YES (Above)	NO (Below)	
<b>GENERAL</b>				
Water Level (above or below principal spillway)			X	1.4 FT BELOW
<b>EROSION</b>				
Rills & Gullies on Embankment			X	
Wave Erosion			X	
Spillway Erosion			X	
Burrows			X	
Other			X	
<b>STRUCTURAL</b>				
Differential Settling			X	
Cracks or Slides			X	
Seepage			X	
Other			X	
<b>STRUCTURES</b>				
Principal Spillway				
Clogged Orifice			NA	
Clogged or Damaged Culvert			NA	
Damaged Headgate			NA	
Emergency Spillway				
Erosion			X	
Riprap			X	
Clogged or Damaged Culvert			NA	
Other			X	
<b>MAINTENANCE</b>				
Maintenance Required			X	
Maintenance Performed			X	
Additional Comments			X	

Mining Area Date Inspected Impoundment NPDES ID No Owner's Rep	Seneca II West Mine	Facility Configuration Date Last Inspected Pond Location Site Location Inspector	Stockpond	Quarterly Impoundment Inspection Form
	6/17/2021		3/22/2021	
	Stock Tank T-24		SW¼NE¼, Sec 9, T5N, R88W	
	N/A		8 mi S of Hayden, CO	
	Miranda Kawcak		Jason Herden	
Mark or Write in Appropriate Response:				
FEATURE	PROBLEM		COMMENTS	
	YES (Above)	NO (Below)		
GENERAL				
Water Level (above or below principal spillway)		X	0 GPM	
EROSION				
Rills & Gullies on Embankment		X		
Wave Erosion		X		
Spillway Erosion		X		
Burrows		X		
Other		X		
STRUCTURAL				
Differential Settling		X		
Cracks or Slides		X		
Seepage		X		
Other		X		
STRUCTURES				
Principal Spillway				
Clogged Orifice		NA		
Clogged or Damaged Culvert		NA		
Damaged Headgate		NA		
Emergency Spillway				
Erosion		X		
Riprap		X		
Clogged or Damaged Culvert		NA		
Other		X		
MAINTENACE				
Maintenance Required		X		
Maintenance Performed		X		
Additional Comments		X		

<b>Mining Area</b> <b>Date Inspected</b> <b>Impoundment</b> <b>NPDES ID No</b> <b>Owner's Rep</b>	Seneca II West Mine	<b>Facility Configuration</b> <b>Date Last Inspected</b> <b>Pond Location</b> <b>Site Location</b> <b>Inspector</b>	Stockpond	<b>Quarterly Impoundment Inspection Form</b>
	6/17/2021		3/22/2021	
	Stock Tank T-25		SW¼NE¼, Sec 34, T5N, R88W	
	N/A		8 mi S of Hayden, CO	
	Miranda Kawcak		Jason Herden	
<b>Mark or Write in Appropriate Response:</b>				
FEATURE		PROBLEM		COMMENTS
		YES (Above)	NO (Below)	
<b>GENERAL</b>				
Water Level (above or below principal spillway)			N/A	0 GPM
<b>EROSION</b>				
Rills & Gullies on Embankment			N/A	
Wave Erosion			N/A	
Spillway Erosion			N/A	
Burrows			N/A	
Other			N/A	
<b>STRUCTURAL</b>				
Differential Settling			N/A	
Cracks or Slides			N/A	
Seepage			N/A	
Other			N/A	
<b>STRUCTURES</b>				
Principal Spillway				
Clogged Orifice			N/A	
Clogged or Damaged Culvert			N/A	
Damaged Headgate			N/A	
Emergency Spillway				
Erosion			N/A	
Riprap			N/A	
Clogged or Damaged Culvert			N/A	
Other			N/A	
<b>MAINTENANCE</b>				
Maintenance Required			X	DAM REMOVED FALL 2011, REBUILT IN 2012 AS A RUNOFF CONTROL STURCURE (PM1-A3)
Maintenance Performed			X	
Additional Comments		X		

<b>Mining Area</b> <b>Date Inspected</b> <b>Impoundment</b> <b>NPDES ID No</b> <b>Owner's Rep</b>	Seneca II West Mine	<b>Facility Configuration</b> <b>Date Last Inspected</b> <b>Pond Location</b> <b>Site Location</b> <b>Inspector</b>	Stockpond	<b>Quarterly Impoundment Inspection Form</b>
	6/17/2021		3/22/2021	
	Stock Tank T-26		NE¼NW¼, Sec 35, T5N, R88W	
	N/A		8 mi S of Hayden, CO	
	Miranda Kawcak		Jason Herden	
<b>Mark or Write in Appropriate Response:</b>				
FEATURE		PROBLEM		COMMENTS
		YES (Above)	NO (Below)	
<b>GENERAL</b>				
Water Level (above or below principal spillway)			X	2.1 FT BELOW
<b>EROSION</b>				
Rills & Gullies on Embankment			X	
Wave Erosion			X	
Spillway Erosion			X	
Burrows			X	
Other			X	
<b>STRUCTURAL</b>				
Differential Settling			X	
Cracks or Slides			X	
Seepage			X	
Other			X	
<b>STRUCTURES</b>				
Principal Spillway				
Clogged Orifice			NA	
Clogged or Damaged Culvert			NA	
Damaged Headgate			NA	
Emergency Spillway				
Erosion			X	
Riprap			X	
Clogged or Damaged Culvert			NA	
Other			X	
<b>MAINTENANCE</b>				
Maintenance Required			X	
Maintenance Performed			X	
Additional Comments			X	



<b>Mining Area</b> <b>Date Inspected</b> <b>Impoundment</b> <b>NPDES ID No</b> <b>Owner's Rep</b>	Seneca II West Mine	<b>Facility Configuration</b> <b>Date Last Inspected</b> <b>Pond Location</b> <b>Site Location</b> <b>Inspector</b>	Stockpond	<b>Quarterly Impoundment Inspection Form</b>
	6/17/2021		3/22/2021	
	Stock Tank T-27		NW¼NW¼, Sec 35, T5N, R88W	
	N/A		8 mi S of Hayden, CO	
	Miranda Kawcak		Jason Herden	
<b>Mark or Write in Appropriate Response:</b>				
FEATURE		PROBLEM		COMMENTS
		YES (Above)	NO (Below)	
<b>GENERAL</b>				
Water Level (above or below principal spillway)			N/A	2.3 FT BELOW
<b>EROSION</b>				
Rills & Gullies on Embankment			N/A	
Wave Erosion			N/A	
Spillway Erosion			N/A	
Burrows			N/A	
Other			N/A	
<b>STRUCTURAL</b>				
Differential Settling			N/A	
Cracks or Slides			N/A	
Seepage			N/A	
Other			N/A	
<b>STRUCTURES</b>				
Principal Spillway				
Clogged Orifice			N/A	
Clogged or Damaged Culvert			N/A	
Damaged Headgate			N/A	
Emergency Spillway				
Erosion			N/A	
Riprap			N/A	
Clogged or Damaged Culvert			N/A	
Other			N/A	
<b>MAINTENANCE</b>				
Maintenance Required			X	REBUILT IN 2012 AS A RUNOFF CONTROL STRUCTURE.
Maintenance Performed			X	
Additional Comments		X		

# IMPOUNDMENT INSPECTION LOG

## JOB DATA

JOB NAME: PEC Hydrologic Services	CLIENT: Peabody	JOB(s): 2021-095 (PSCM), 2021-096 (SCC)
-----------------------------------	-----------------	---

## FLOW DATA

SITE ID	COMPANY	MINE	DATE	WATER LEVEL (FT)	OUTFLOW (GPM)	OBSERVATIONS	MAINTENANCE (Y/N)
002	Sage Creek	Sage Creek	6-15-21	0.0	43.6	all water going under Flume	Y
003	Sage Creek	Sage Creek	6-15-21	0.10	2.1	Culvert Flume broken, animal burrows	N
004	Sage Creek	Sage Creek	6-17-21	0.15	44.9		N
Lower Sump	Sage Creek	Sage Creek	6-17-21	0.1	87.6		N
PECOCO	Sage Creek	Sage Creek	6-17-21	0.1	97.8		N
Portal Sump 1	Sage Creek	Sage Creek	6-17-21	—	—	no Flow	N
Portal Sump 2	Sage Creek	Sage Creek	6-17-21	0.1	—	not pumping	N
Spill Control 2	Sage Creek	Sage Creek	6-17-21	—	—	Dry	N
Truck Wash	Sage Creek	Sage Creek	6-17-21	—	—	Dry	N
Upper Sump	Sage Creek	Sage Creek	6-17-21	0.1	87.6		N
001	Seneca	Hayden Gulch	6-17-21	-2.0	—	NO Flow	N
002	Seneca	Hayden Gulch	6-17-21	-3.0	—	NO Flow	N
005	Seneca	Seneca II West	6-14-21	-1.5	—	NO Flow spring @ Pan no impact	N
006	Seneca	Seneca II West	6-14-21	0.1	42.1	stuff on S. side, no impact	N
009	Seneca	Seneca II West	6-14-21	-2.5	—	no Flow	N
015	Seneca	Seneca II West	6-14-21	-1.3	—	NO Flow	N
016	Seneca	Seneca II West	6-14-21	0.1	63.4	small seep	Y
017	Seneca	Seneca II West	6-14-21	0.1	1.0		N
T-1	Seneca	Seneca II West	6-17-21	—	—	Dry	N
T-18	Seneca	Seneca II West	6-17-21	-2.3	—	no Flow	N
T-2	Seneca	Seneca II West	6-17-21	—	—	Dry	N
T-20	Seneca	Seneca II West	6-17-21	-3.4	—	no Flow	N
T-22	Seneca	Seneca II West	6-17-21	-1.4	—	no Flow	N
T-24	Seneca	Seneca II West	6-17-21	—	—	Dry	N
T-25	Seneca	Seneca II West	6-17-21	—	—	Dry	N
T-26	Seneca	Seneca II West	6-17-21	-2.1	—	NO Flow	N

008

6-14-21 0.1 2.3 outlet pipe broken

Y

SITE ID	COMPANY	MINE	DATE	WATER LEVEL (FT)	OUTFLOW (GPM)	OBSERVATIONS	MAINTENANCE (Y/N)
T-27	Seneca	Seneca II West	6-17-21	-3.3	-	No Flow	N
T-3	Seneca	Seneca II West	6-17-21	-3.1	-	No Flow	N
T-5	Seneca	Seneca II West	6-17-21	-3.3	-	No Flow	N
010	Seneca	Yoast	6-14-21	-0.2	-	No Flow, outlet rusted, cat tails	Y
011	Seneca	Yoast	6-14-21	-1.3	-	No Flow	N
011A	Seneca	Yoast	6-15-21	-1.5	-	No Flow	N
012	Seneca	Yoast	6-14-21	0.1	57.7		N
012A	Seneca	Yoast	6-16-21	-1.0	-	No Flow	N
013	Seneca	Yoast	6-14-21	-1.0	-	No Flow	N
014	Seneca	Yoast	6-14-21	-1.3	-	No Flow	N
ST-1	Seneca	Yoast	6-17-21	-1.6	-	No Flow	N

FIELD PERSONNEL: JH	FIELD PERSONNEL SIGNATURE: 
---------------------	--

## NOTES

[illegible]