



ORIGINAL PERMIT APPLICANT(S)

MA CONCRETE CONSTRUCTION INC (ANDY)

APPROVED WELL LOCATION

Water Division: 5 Water District: 72
Designated Basin: N/A
Management District: N/A
County: MESA
Parcel Name: N/A
Physical Address: N/A

NW 1/4 SW 1/4 Section 26 Township 1.0 N Range 2.0 W Ute P.M.

UTM COORDINATES (Meters, Zone:13, NAD83)

Easting: 181845.1 Northing: 4337232.2

PERMIT TO EXPOSE WATER IN A EXISTING PIT

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-90-137 (2) and (11) for the construction and operation of a well (gravel pit pond) exposing and diverting groundwater tributary to the Colorado River at a point where water is available for appropriation. This well is known as the 20 Road Pit, Division of Reclamation, Mining & Safety Permit Number M-2005-061.
- 4) The approval of this permit does not grant a water right. This well (gravel pit pond) is subject to administration by the Division Engineer in accordance with applicable decrees, statutes, rules and regulations.
- 5) The annual amount of groundwater to be appropriated shall not exceed 52.26 acre-feet with the total surface area of groundwater exposed to the atmosphere at the site limited to 11 acres.
- 6) The use of groundwater, in addition to dewatering at a rate of 500 GPM and evaporation, is limited to dust control and product moisture loss with the mined product. No other use of water is allowed unless a permit therefor is approved.
- 7) The owner shall mark the well (gravel pit pond) in a conspicuous place with well permit number(s) and court case number(s) as appropriate. The owner shall take necessary means and precautions to preserve these markings.
- 8) A totalizing flow meter must be installed so as to measure any pumping from this gravel pit pond and maintained in good working order. Permanent records of all diversions from the gravel pit pond, tonage of mined product, and the surface area of groundwater exposure shall be maintained by the well owner (recorded at least annually) and submitted to the Division Engineer upon request.
- 9) Pursuant to Rule 9.3.3 of the Water Well Construction Rules, groundwater ponds and gravel pit wells are exempt from the minimum well construction and location standards except for contamination considerations as stated in the Rule. The owner shall take necessary means and precautions to prevent contaminants from entering the groundwater pond or gravel pit well.
- 10) Pursuant to Rule 17.1.5 of the Water Well Construction Rules, the owner shall submit, after initiation of construction, site plan and cross section drawings showing the extent of intended excavation, the maximum depth of the pit or pond, the initial static water level, and the date of initial groundwater exposure to the atmosphere.
- 11) The boundaries of the gravel pit pond shall be located more than 600 feet from any existing well, completed in the same aquifer, that is not owned by the applicant, excluding those wells whose owners were notified pursuant to CRS 37-90-137(2)(b)(II)(A).

NOTE: This well may be subject to administration in the water rights priority system in the future. It is recommended that a water court decree be obtained to affirm the priority of the well.

WELL PERMIT NUMBER 88165-F

RECEIPT NUMBER 10028733



Date Issued: 6/6/2023

Expiration Date: N/A

Issued By JUSTINA MICKELSON