

Field testing results
GW Monitoring

Readings Taken
using a Calibrated
APERA PC60 unit

	PH	Specific Conductance	Temperature (Fahrenheit)	TDS	Salinity
3/31/2023		1245 7.54 MicroSiemens		56.1 Not taken	Not taken
6/13/2023		1239 7.56 MicroSiemens		56 877 ppm	.62 ppt
9/27/2023		1241 7.58 MicroSiemens		55.9 889 ppm	.63 ppt
12/7/2023		1246 7.57 MicroSiemens		56.1 885 ppm	.63 ppt
3/29/2024		1240 7.55 MicroSiemens		56 880 pp,	.62 ppt