

Metal	date from	date to	sample Measurement Cross	NPDWR levels *	Notes
			ug/L	ug/L	
lead	6/1/2021	6/30/2021	12	15	Meets Tap water levels
lead	12/1/2020	12/31/2020	4.4	15	Meets Tap water levels
lead	1/1/2021	1/31/2021	10	15	Meets Tap water levels
lead	4/1/2021	4/31/2021	6.2	15	Meets Tap water levels
lead	7/1/2021	7/31/2021	8	15	Meets Tap water levels
cadmium	8/1/2021	8/31/2021	1.5	5	Meets Tap water levels
zinc	8/1/2021	8/31/2021	282	no level violation	Meets Tap water levels
Silver	1/1/2021	1/31/2021	0.4	no level violation	Meets Tap water levels
copper	1/1/2021	1/31/2021	34.5	130	Meets Tap water levels
copper	3/1/2021	3/31/2021	46.75	130	Meets Tap water levels
copper	4/1/2021	4/31/2021	50	130	Meets Tap water levels
* National Primary Drinking Water Regulations US EPA					