

2720 Ruby Vista Drive
Suite 101
Elko, Nevada 89801
775.777.8003
www.Linkan.com

To: Department of Natural Resources Division of Reclamation, Mining and Safety	Attention:	Peter Hays
Division of Rectaination, winning and Safety	Re:	Schwartzwalder WTP
	Job Number:	25-US-0221

Field Service Report		
Site: Schwartzwalder Mine	Location: Golden, CO	
Site Contact: Peter Hays	Date: 04/02/2025	
Service Request Description: Transition at Startup / Plant Commissioning		

Description of Service

- Onsite for potable water delivery. Filled both tanks behind lab trailer with potable water

- Found leak in copper piping inside the lab trailer after receiving delivery of potable water. Isolated section of piping to be replaced

- Found leak in fittings before pump in trailer. Fittings to be investigated further and replaced.

- Potable water tank was left isolated from lab trailer due to leaks in fittings. Heat trace turned on to prevent freezing damage.

Equipmnet Used:	
	Signature
	Signature