

| 2720 Ruby Vista Drive Suite 101 Elko, Nevada 89801 775.777.8003 www.Linkan.com | | | |
|--|----------------------|--------------------|--|
| To: Department of Natural Resources | Attention: | Peter Hays | |
| Division of Reclamation, Mining and Safety | Re: | Schwartzwalder WTP | |
| | Ke: | Schwartzwalder w1r | |
| | Job Number: | 25-US-0221 | |
| Field Service Report | | | |
| Site: Schwartzwalder Mine | Location: Golden, CO | | |
| Site Contact: Peter Hays | Date: 05/09/2025 | | |
| Service Request Description: Transition at Startup / Plant | Commissioning | | |
| L | | | |
| Description of Service | | | |

- Measured MW-18: 173.3 ft
- Measured Jeffery Mine Shaft: 140.2 ft
- Patrick Delaney and Matt Sturrock (electrician) onsite.
- Fixed the leak on the jet pump that feeds the lab bathroom as well as the leaking copper line.
- Staged electrical, conduit and wire at the head frame.
- Staged parts for the anti-scale dosing upgrade.
- Staged parts for surge protection.

| Equipment Used: | | |
|-----------------|-----------|----------------|
| | Signature | Bryant Acevedo |









1 5006 eNGE-fs ULe 5102.2 ASTH EA4 FS<=25/5D<=5









