




Schwartzwalder Daily Summary Report



Report Date:	8/12/2025	Lead Operator:	Chris P
		Assistant Operator(s):	Patrick D

Effluent Discharged:	0.287 Mgal	MW-18 Level:	207.6 ft	90.3 ft
Average Flowrate:	205.4 gpm	Transducer Level:	212.6 ft	83.4 ft
Effluent to Date:	12.430 Mgal	(Field Reading Value below 150')		



Finished Water Quality			
Parameters	Temp	pH	Cond
Values	21°C	7.55	192 µS/cm

Chemical Inventory			
Chemicals	Antiscalant	NaOH	BaCl
0>,mnbv /	5 Gal	23 Gal	2 Gal
Vol. Remaining	197 Gal	152 Gal	41 Gal
Vol. Staged	460 Gal	780 Gal	160 Gal
Days Available	131 Days	41 Days	101 Days

Safety Issues/Concerns:

- N/A

Notes:

- Collected and Shipped Table 1 Bi-weekly and Minepool Quarterly Samples.

NOTE: The level graph has been adjusted to show field readings relative to the water level below the compliance elevation (150' below the Steve Adit - 6459' ASL). Data from 5/1/2025 to 6/5/2025 was recorded using an atmospheric transducer with a 500-ft cable, installed at the end of the 2024 season and remained in place over the winter. On 6/6/2025, it was replaced with an absolute transducer with a 600-ft cable at a lower depth. A 77.1-ft difference in readings was observed. While some of offset may be a result from the deeper installation and transducer type, the old data's accuracy is questionable due to damage to the atmospheric vent, which may have allowed moisture intrusion.