




Schwartzwalder Daily Summary Report



Report Date:	8/18/2025	Lead Operator:	Bryant A
		Assistant Operator(s):	

Effluent Discharged:	0.281 Mgal	MW-18 Level:	217.3 ft	100.0 ft
Average Flowrate:	204.1 gpm	Transducer Level:	197.2 ft	98.8 ft
Effluent to Date:	13.915 Mgal	(Field Reading Value below 150')		



Finished Water Quality			
Parameters	Temp	pH	Cond
Values	21°C	7.5	179 µS/cm

Chemical Inventory			
Chemicals	Antiscalant	NaOH	BaCl
Vol. Used	7 Gal	23 Gal	3 Gal
Vol. Remaining	152 Gal	161 Gal	42 Gal
Vol. Staged	460 Gal	905 Gal	130 Gal
Days Available	87 Days	46 Days	57 Days

Safety Issues/Concerns:

- N/A

Notes:

- Collected Outfall 001A Weekly TSS Sample.
- Raised VFD Pump Hertz from 59.5Hz to 59.78Hz.
- Prepped Cartridge Filter Area for Cartridge Filter replacement.

NOTE: The level graph has been adjusted to show field readings relative to the water level below the compliance elevation (150' below the Steve Adit - 6459' ASL). Data from 5/1/2025 to 6/5/2025 was recorded using an atmospheric transducer with a 500-ft cable, installed at the end of the 2024 season and remained in place over the winter. On 6/6/2025, it was replaced with an absolute transducer with a 600-ft cable at a lower depth. A 77.1-ft difference in readings was observed. While some of offset may be a result from the deeper installation and transducer type, the old data's accuracy is questionable due to damage to the atmospheric vent, which may have allowed moisture intrusion.