




Schwartzwalder Daily Summary Report



Report Date:	8/22/2025	Lead Operator:	Patrick D
		Assistant Operator(s):	Bryant A

Effluent Discharged:	0.834 Mgal	MW-18 Level:	224.9 ft	107.6 ft
Average Flowrate:	200.7 gpm	Transducer Level:	187.9 ft	108.1 ft
Effluent to Date:	15.699 Mgal	(Field Reading Value below 150')		



Finished Water Quality			
Parameters	Temp	pH	Cond
Values	20°C	6.98	182 µS/cm

Chemical Inventory			
Chemicals	Antiscalant	NaOH	BaCl
Vol. Used	14 Gal	43 Gal	7 Gal
Vol. Remaining	332 Gal	192 Gal	50 Gal
Vol. Staged	230 Gal	770 Gal	400 Gal
Days Available	40 Days	22 Days	64 Days

Safety Issues/Concerns:

- N/A

Notes:

- Transferred 22 gallons of 50% NaOH.
- Batched 20 gallons of BaCl.
- Replaced RO#1 Anti scalant tote with New Full Tote.
- Washed out 2x NaOH Totes and 1x Anti Scalant Tote using RO#1 Permeate. This caused Plant Flow too drop and pH too spike. Still within Operating Parameters.