




Schwartzwalder Daily Summary Report



Report Date:	9/16/2025	Lead Operator:	Bryant A	
		Assistant Operator(s):		

Effluent Discharged:	0.250 Mgal	MW-18 Level:	263.4 ft	146.1 ft
Average Flowrate:	180.5 gpm	Transducer Level:	99.7 ft	196.3 ft
Effluent to Date:	21.973 Mgal	(Field Reading Value below 150')		



Finished Water Quality			
Parameters	Temp	pH	Cond
Values	20°C	7.39	201 µS/cm

Chemical Inventory			
Chemicals	Antiscalant	NaOH	BaCl
Vol. Used	7 Gal	22 Gal	4 Gal
Vol. Remaining	392 Gal	146 Gal	37 Gal
Vol. Staged	0 Gal	270 Gal	300 Gal
Days Available	56 Days	19 Days	84 Days

Safety Issues/Concerns:

- N/A

Notes:

- Collected and shipped Outfall 001A Weekly TSS and COD samples.

NOTE: For the level graph, Data from 5/1/2025 to 6/5/2025 was recorded using an atmospheric transducer with a 500-ft cable, installed at the end of the 2024 season. On 6/6/2025, it was replaced with an absolute transducer with a 600-ft cable (lower depth). A 77.1-ft difference in readings was observed. MW-18 ran dry effective 9/2/2025. Assume a decline of 1.5125 ft per day for the projected MW-18 depth effective 9/2/2025. On 9/4/2025, the transducer was temporarily removed from the casing to verify the minepool water depth. The transducer was recalibrated to align with the field readings resulting in a difference of 30.4 ft lower than previously indicated.