



**ORIGINAL PERMIT APPLICANT(S)**

SOUTHWEST READY-MIX

**APPROVED WELL LOCATION**

Water Division: 3      Water District: 20  
 Designated Basin: N/A  
 Management District: N/A  
 County: ALAMOSA  
 Parcel Name: N/A  
 Physical Address: N/A

NW 1/4 SE 1/4 Section 36 Township 38.0 N Range 10.0 E New Mexico P.M.

**UTM COORDINATES (Meters, Zone:13, NAD83)**

Easting: 427015.0      Northing: 4150061.0

**PERMIT TO EXPOSE WATER IN A EXISTING PIT**

**ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT OR GUARANTEE WATER AVAILABILITY  
CONDITIONS OF APPROVAL**

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-90-137 (2) and (11) for the operation of a well (gravel pit pond) on the condition that this well is operated in accordance with the San Luis Valley Water Conservancy District Augmentation Plan (One-Time Sale Agreement 2025-08) approved by the Division 3 Water Court in Case Nos. 84CW0016; 94CW0062; 03CW0041; 05CW0013; 07CW0063; 09CW0034; and 14CW3011. The well (pond) shall not be operated unless under an approved augmentation agreement, included in a substitute water supply plan approved by the State Engineer or under a plan for augmentation approved by the Water Court. The water supply plan for this pit is currently valid through December 31, 2025, and if it is not renewed or if a court decree is not entered for a plan for augmentation, diversion of groundwater from this well must cease immediately.
- 4) The use of groundwater, under SLVWCD One Time Sale Agreement 2025-08, is limited to the washing of 4,000 tons of aggregate. This permit also authorizes the replacement of evaporative losses from the gravel pits. No other use of water is allowed unless a well permit therefore is approved.
- 5) The annual amount of groundwater to be appropriated by this well (pond), under SLVWCD One Time Sale Agreement 2025-08, shall not exceed 22.36 acre-feet of consumptive use of which 0.12 acre-feet is allocated for the consumptive use associated with washing 4,000 tons of aggregate and 22.24 acre-feet of consumptive use is allocated to the replacement of evaporative losses from 6 acres of surface area exposed to the atmosphere.
- 6) The total surface area of groundwater exposed to the atmosphere by this gravel pit is limited to a maximum of 6 acres.
- 7) The owner shall mark the well (gravel pit pond) in a conspicuous place with well permit number(s) and court case number(s) as appropriate. The owner shall take necessary means and precautions to preserve these markings.
- 8) The boundaries of the gravel pit pond shall be located more than 600 feet from any existing well, completed in the same aquifer, that are not owned by the applicant.
- 9) Pursuant to Rule 9.3.3 of the Water Well Construction Rules, groundwater ponds and gravel pit wells are exempt from the minimum well construction and location standards except for contamination considerations as stated in the Rule. The owner shall take necessary means and precautions to prevent contaminants from entering the groundwater pond or gravel pit well.
- 10) This well is subject to administration by the Division Engineer in accordance with applicable decrees, statutes, rules, and regulations.

NOTE: The well structure I.D. # (WDID) is 2014690.

WELL PERMIT NUMBER 90307-F

RECEIPT NUMBER 10039684



Date Issued: 9/26/2025

Issued By DARIN SCHEPP

Well must be constructed by N/A