



PLANT SYSTEMS GROUP - SALT LAKE CITY, UTAH

CALCULATION COVER SHEET

JOB NUMBER	CLIENT	PROJECT	CALC. NUMBER
11021	CC&V	High Grade Ore	C-001


TITLE/SUBJECT:

Grassy Valley Pipeline
Mill Water Tank Ring Wall Foudnation

STATEMENT OF PROBLEM:

Design the foundation for a 45'-0 diameter soil supported water tank. Design the pump foundations for the new pumps in Grassy Valley.

P.E. SEAL




SOURCES OF DATA, FORMULA & REFERENCES:

AutoDesk Robot Structural Analysis Professional 2012
Mechanical Drawing on proposed water tank
ASCE /SEI 7-10 for Wind Load and Seismic Load
ACI 350.3 Appendix B (Sloshing)
AMEC Soils Report

CONCLUSIONS & RECOMMENDATIONS:

See details in report

A	Oct-11	Ready for Check	Wchan	ES		
0	Jul-12	Issued for Permit	Wchan	ES		
REV	DATE	DESCRIPTION/STATUS	CALC BY	CHKD BY	DWG./SPECS REVISED	QA REVIEW



Load Applied:

$$\begin{aligned}
 \text{Tank DL} &= 3/8" \times (\pi r h + \pi r^2 + \pi r L) \times 490 \text{ psf} \\
 &= (3/8)/12 \times [\pi (45) (35) + \pi (45)^2/4 + \pi (22.5) (25.98)] \times 0.49 \text{ ksi} \\
 &= 128.24 \text{ kips}
 \end{aligned}$$

$$\begin{aligned}
 \text{Distribute DL on top of ring wall rim} &= 128.24 / 2\pi r = 128.24 / 45\pi \\
 &= 0.907 \text{ kip/ft}
 \end{aligned}$$

$$\text{Material LL} = 62.4 \text{ psf} \times \pi r^2 \times h = 0.0624 \times \pi (45)^2/4 \times 35 = 3473.5 \text{ kips}$$

$$\text{Distribute LL on bottom of tank} = 3473.5 / \pi r^2 = 3473.5 / (\pi (45)^2/4) = 2.184 \text{ ksi}$$

$$\text{Snow L} = 40 \text{ psf}$$

$$\text{Distribute snow on the rim} = 40 \text{ psf} \times \pi r L / 2\pi r = 40 \times \pi (22.5) (25.98) / 45\pi = 0.519 \text{ kip/ft}$$

	PROJECT	PROJ NO. 11021
		CALC. NO. C-001
	SUBJECT	BY Wchm DATE 10/14/2011
		CHK DATE
		SHEET OF REV

Wind Load =

$$V = 90 \text{ mph}$$

$$Exp = C$$

$$K_{zt} = 1.0$$

$$G = 0.85$$

$$K_z = 1.04$$

$$K_d = 0.95$$

$$\begin{aligned} q_z &= 0.00256 (K_z) (K_{zt}) (K_d) V^3 \\ &= 0.00256 (1.04) (1.0) (0.95) 90^3 \\ &= 30.487 \end{aligned}$$


$$F = q_z G C_f A_g$$

$$\begin{aligned} DF_{32} &= 45 \sqrt{20.980} \\ &= 203.63 > 2.5 \end{aligned}$$

$$\therefore C_f = 0.7$$

$$\begin{aligned} \frac{F}{A_g} &= 30.487 (0.85) (0.7) \\ &= 12.18 \text{ psf} \end{aligned}$$

Distribute along top rim of ring wall as coupling load:



$$\begin{aligned} 12.18 \text{ psf} \times 35' \times 45' \times 17.5' &= W_z \text{ '45'} \\ \hline 1000 & W_z = 7.46 \text{ kips} \end{aligned}$$

$$\begin{aligned} \text{Distribute along the rim (half)} & \\ &= W_z / \frac{1}{2} (280') \\ &= 7.46 / \frac{1}{2} (280') = 0.1055 \text{ kip/ft.} \end{aligned}$$

Seis Load =


For rigid non-building structure, $C_s = 0.064$.

$$V = C_s W$$

$$\begin{aligned} V &= 0.064 (123.24) \\ &= 8.207 \text{ kips} \end{aligned}$$

Distribute along top rim of ring wall as coupling load:

	PROJECT	PROJ NO.
		CALC NO.
	SUBJECT	BY DATE
		CHK DATE
		SHEET OF REV



$$8.257 \left(\frac{2}{3} \right) 55' = \text{Seis } E \text{ (45')}$$

$$\text{Seis } E = 4.255 \text{ kips}$$

$$\text{Distributable Long run (half)} \\ = \text{Seis } E / \frac{1}{2} (\text{corr})$$

$$= 4.255 / \left(\frac{1}{2} \right) = 0.66 \text{ kip / ft.}$$

$$\text{Base Shear from shaking} = 199.29 \text{ kip / 45 ft} \\ \text{(by MathCAD worksheet)} = 1.4097 \text{ k / ft}$$

$$\text{Allowable Soil bearing (by AMEC soil report)} = 3500 \text{ psf.}$$

Seismic Design of Steel Circular Tanks

per ACI 350.3, ASCE 7-05

Tank Properties:

$$D := 45\text{ft}$$

Tank Diameter

$$H := 35\text{ft}$$

Height of Tank

Seismic Properties:

$$S_a := .213$$

Spectral Acceleration (% of g)

$$I := 1.0$$

Importance Factor

$$R := 3$$

Response Factor

$$u_v := 0.043$$

Vertical Acceleration (% of g)

Material Properties:

$$W_L := 3473500\text{lb}$$

Weight of Material

$$W_w := 100120\text{lb}$$

Weight of Tank

$$W_r := 28120\text{lb}$$

Weight of Roof

$$W_i := \frac{\tanh\left(0.866 \cdot \frac{D}{H}\right) \cdot W_L}{0.866 \cdot \left(\frac{D}{H}\right)} = 2.512 \times 10^3 \cdot \text{kip}$$

Weight of Impulsive Material

$$W_c := 0.230 \cdot \left(\frac{D}{H}\right) \cdot \tanh\left(3.68 \cdot \frac{H}{D}\right) \cdot W_L = 1.02 \times 10^3 \cdot \text{kip}$$

Weight of Convective Material

Force Center of Gravity:

$$h_w := \frac{H}{2} = 17.5 \cdot \text{ft}$$

Wall Center of Gravity

$$h_r := H = 35 \cdot \text{ft}$$

Roof Center of Gravity

$$h_i := 0.375 \cdot H = 13.125 \cdot \text{ft}$$

Impulsive Center of Gravity

$$h_c := \left[1 - \frac{\cosh\left(3.68 \cdot \frac{H}{D}\right) - 1}{3.68 \cdot \left(\frac{H}{D}\right) \cdot \sinh\left(3.68 \cdot \frac{H}{D}\right)} \right] \cdot H = 24.094 \cdot \text{ft}$$

Convective Center of Gravity

Vertical Forces:

$$P_v := u_v \cdot W_w = 4.305 \cdot \text{kip}$$

Force due to Wall

$$P_r := u_r \cdot W_r = 1.209 \cdot \text{kip}$$

Force due to Roofl

$$q_h := \gamma \cdot H = 0.09 \frac{\text{s}^2 \cdot \text{in}^2}{\text{lb}} \cdot \text{ksf}$$

Liquid Pressure

$$Q_h := q_h \cdot \left(\frac{D}{2} \right) = 2.034 \times 10^3 \frac{\text{s}^2 \cdot \text{in}^2}{\text{lb}} \cdot \text{plf}$$

Liquid Force per ft of Wall

Shear Forces:

$$\bar{\varepsilon}_w := \min \left[0.0151 \left(\frac{D}{H} \right)^2 - 0.1908 \left(\frac{D}{H} \right) + 1.021, 1 \right] = 0.801$$

Effective Mass Coefficient

$$P_w := \frac{S_a \cdot I \cdot \bar{\varepsilon}_w \cdot W_w}{R} = 5.691 \cdot \text{kip}$$

Base Shear due to Wall

$$P_r := \frac{(S_a) \cdot I \cdot \bar{\varepsilon}_w \cdot W_r}{R} = 1.599 \cdot \text{kip}$$

Base Shear due to Roof

$$P_i := \frac{S_a \cdot I \cdot W_i}{R} = 178.363 \cdot \text{kip}$$

 Base Shear due to
Impulsive Weight

$$P_c := \frac{S_a \cdot I \cdot W_c}{R} = 72.454 \cdot \text{kip}$$

 Base Shear due to
Convective Weight

$$V_w := \sqrt{(P_i + P_w + P_r)^2 + P_c^2} = 199.29 \cdot \text{kip}$$

Total Base Shear

Overturning Forces:

$$M_w := P_w \cdot h_w = 99.6 \cdot \text{kip} \cdot \text{ft}$$

Overturning Moment due to Wall

$$M_r := P_r \cdot h_r = 55.948 \cdot \text{kip} \cdot \text{ft}$$

Overturning Moment due to Wall

$$M_i := P_i \cdot h_i = 2.341 \times 10^3 \cdot \text{kip} \cdot \text{ft}$$

 Overturning Moment due
to Impulsive Force

$$M_c := P_c \cdot h_c = 1.746 \times 10^3 \cdot \text{kip} \cdot \text{ft}$$

 Overturning Moment due
to Convective Force

$$M := \sqrt{(M_i + M_w + M_r)^2 + M_c^2} = 3.046 \times 10^3 \cdot \text{kip} \cdot \text{ft}$$

Total Overturning Moment

Unanchored Tank Requirements:

Per AWWA D100 Section 13.3

$$t_b := 0.1875 \text{ in}$$

Tank Bottom Thickness

$$\sigma_y := 36 \text{ ksi}$$

Tank Yield Stress

$$\gamma := 62.4 \text{ pcf}$$

Unit weight of tank material

Overturning Check:

$$w_L := \min(t_b \cdot \sqrt{\sigma_y \cdot H \cdot \gamma}, 0.02 \cdot H \cdot D \cdot \gamma) = 1.663 \times 10^3 \cdot \frac{\text{lb} \cdot \text{ft}}{\text{ft}}$$

Maximum weight of tank contents per length of shell

$$w_t := \frac{(W_w + W_r)}{\pi \cdot D} = 0.907 \cdot \frac{\text{kip}}{\text{ft}}$$

Weight of Tank Shell and Roof per length of Shell

$$M_r := (w_L + w_t) \cdot (\pi \cdot D) \cdot \frac{D}{2} = 8.174 \times 10^3 \cdot \text{kip} \cdot \text{ft}$$

Overturning Resistance

$$\text{OverturningRatio} := \frac{M_r}{M} = 2.683$$

Overturning Ratio

Sliding Check:

$$\mu := 0.3$$

Friction Coefficient

$$V_r := (W_L + W_w + W_r) \cdot \mu = 1.081 \times 10^3 \cdot \text{kip}$$

Sliding Resistance

$$\text{SlidingRatio} := \frac{V_r}{V} = 5.422$$

Sliding Ratio

Annulus Plate Design:

$$t_s := 0.375 \text{ in}$$

Tank Annulus Thickness

$$E := 29000 \text{ ksi}$$

Modulus of Elasticity

$$L := 1.7 \cdot t_b \cdot \sqrt{\frac{\sigma_y}{H \cdot \gamma}} = 1.294 \cdot \text{ft}$$

Annulus Required width

$$L_{\text{limit}} := 0.035 \cdot D = 1.575 \cdot \text{ft}$$

If $L > 0.035D$, Then Tank must be anchored

Seismic Allowable Stress:

$$P := \gamma \cdot H = 15.167 \text{ psi}$$

Hydrostatic Pressure at Base

$$\frac{P}{E} \cdot \left(\frac{D}{2t_s} \right)^2 = 0.271$$

Criteria to be used with Figure 11

$$\Delta C_c := 0.18$$

 Pressure stabilizing buckling coefficient
(From Figure 11)

$$\Delta \sigma_{cr} := \frac{2(\Delta C_c \cdot E \cdot t_s)}{D} = 7.25 \cdot \text{ksi}$$

Critical Buckling Stress

$$\frac{2 \cdot t_s}{D} = 1.389 \times 10^{-3}$$

Criteria to be used with Table 10

$$\sigma_a := 2467 \text{ psi}$$

 Allowable Compression Stress
(from Table 10)

$$\sigma_e := 1.33 \cdot \left(\sigma_a + \frac{\Delta \sigma_{cr}}{2} \right) = 8.102 \cdot \text{ksi}$$

Seismic Allowable Stress

Shell Longitudinal Stress:

$$\text{uplift} := \frac{M}{D^2 \cdot (w_t + w_L)} = 0.585$$

 Uplift Check: uplift occurs if greater than
0.785, and less than 1.54


$$\sigma_{c1} := \left(w_t + \frac{1.273 \cdot M}{D^2} \right) \cdot \frac{1}{t_s} = 0.627 \cdot \text{ksi}$$

Shell Compression Force (no uplift)

$$\sigma_{c2} := \left(\frac{w_t + w_L}{0.607 - 0.187 \cdot \text{uplift}^{0.67}} - w_L \right) \cdot \frac{1}{t_s} = 0.829 \cdot \text{ksi}$$

Shell Compression Force (uplift)

REQ'D TANK BOTTOM = R 3/16"
 REQ'D ANNULUS PLATE = R 3/8"
 REQ'D ANNULUS WIDTH = 1'-4"



Pump Specification

SUCT.FLANGE SIZE	6"	DRILLING	ANSI 300#	FACING	RF	FINISH	SERRATED
DISCH.FLANGE SIZE	3"	DRILLING	ANSI 300#	FACING	RF	FINISH	SERRATED
PUMP ROTATION (LOOKING AT PUMP FROM MOTOR)	CCW						
TYPE OF LUBRICATION	RING OIL					COOLED	NO
TYPE OF STUFFING BOX	STANDARD NON COOLED					COOLED	NO
TYPE OF SEALING	MECHANICAL SEAL						

Weights and Measurements

PUMP	738.0 lb
MOTOR/CPLG	1,615.0/11.0 lb
BASEPLATE	846.0 lb
TOTAL	3,210.0 lb
GR.VOLUME w/BOX	180.5 ft ³
GR.WEIGHT w/BOX	4,113.0 lb

Motor Specification

MOTOR BY	PUMP MFG	MOUNT BY	PUMP MFG	MFG.	PUMP MFG'S CHOICE
FRAME	445TS	POWER	150.0 hp	RPM	3600
PHASE	3	FREQUENCY	60 HZ	VOLTS	460
INSULATION	F	S.F.	1.15		
ENCLOSURE	SEVERE DUTY/MILL AND CHEMICAL PREMIUM EFFICIENCY				

Notes and References


- MTR DIMENSIONS ARE APPROXIMATE
- ALLOW FROM 1.00 to 2.00in. (25 to 51mm) FOR GROUTING. SEE INSTRUCTION BOOK FOR DETAILS.
- ANCHOR BOLTS SUPPLIED BY OTHERS
- * Tolerance is +0.12 -0.25 (+3 -6)
- ** Foundation bolt grip thickness

Auxiliary Specification

COUPLING BY	PUMP MFG	CPLG TYPE	METASTREAM TSCS 0033
CPL GUARD BY	PUMP MFG	CPLG GUARD MATL	STEEL
BASEPLATE	FABRICATED CHANNEL STEEL - MOTOR J/BOX MAY OVERHANG THE BASE PLATE API No 02		
MECH.SEAL	JOHN CRANE 5610Q XF(55)10(58)H		

FOR PUMP TAPPED OPENINGS REFER TO DWG.:
T090111-LD1 / ITEM 001

Typical Anchor Bolt Installation



All dimensions are in : in.(mm).
Drawing is not to scale
Weights lbs (kg) are approximate

DRAWING IS FOR REFERENCE ONLY.
NOT CERTIFIED FOR CONSTRUCTION UNLESS SIGNED.

Customer: QUADNA
Serial No:
Customer P.O. No:
Item No: ITEM 001
End User: RMS
Service:

DRAWING NO 090111-LD1/ITEM 001

Copyright 2012
ITT Corp



PROJECT	CC & V HIGH GRADE CREEK	PROJ NO.	11021
SUBJECT	GRASSY VALLEY	CALC NO.	C-001
	PUMP HOUSE	BY	ECS
		DATE	7-19-12
		CHK	DATE
		SHEET	OF
			REV

Pump Foundation

$$\begin{aligned}\text{DRAIN LOAD} &= \text{PUMP} = 738 \# \\ &\text{MOTOR} = 1,615 \# \\ &\text{BASEPLATE} = 846 \#\end{aligned}$$

$$\text{TOTAL} = \underline{3,210 \#}$$

MAKE FOUNDATION 3-4 TIMES PUMP MASS

$$(3'-6" \times 4'-0" \times 7'-3") (150 \text{ PCF}) = 15,225 \#$$

$$\text{RATIO} = \frac{15,225 \#}{3,210 \#} = 4.7 \quad \underline{\underline{OK}}$$

BEARING PRESSURE (INCLUDING CONCRETE WEIGHT)

$$P = (15,225 \# + 3,210 \#) / (3'-6" \times 7'-3")$$


$$= \underline{\underline{426 \text{ PSF}}}$$

OK


BY INSPECTION, SEISMIC FOUNDATION ANALYSIS ARE NOT NEEDED DUE TO MASS OF CONCRETE & LOW STATIC BEARING PRESSURE

	PROJECT	CC&V HIGH GRADE COR.	PROJ NO.	11021
	SUBJECT	LODGE VALLEY	CALC NO.	6-001
		PUMP HOUSE	BY	ECS
			DATE	7-19-12
			CHK	DATE
			SHEET	OF
				REV

PUMP FOUNDATION



PLAN



ELEVATION