

STATE OF COLORADO
DIVISION OF WATER RESOURCES
OFFICE OF THE STATE ENGINEER
GROUND WATER ADMINISTRATION

PERMIT

NOTE: This permit is issued for the purposes indicated in the application.

RECEIVED

Form C Rev.
9-62/10M

STATE OF COLORADO
APPLICATION FOR: ☒ A PERMIT TO USE GROUND WATER
☒ A PERMIT TO CONSTRUCT A WELL GROUND WATER SECT.

AUG 9 1965

Applicant Mrs. Britt Bell
P.O. Address 215 Cherry, Burlington
Quantity applied for 1500 gpm or 1600 AF Storage
Used for Irrigation Purposes
on/at N 1/2 Sec. 33, T. 10S, R. 43W
(legal description of land site)

LOCATION OF WELL COLORADO
County K. & Carson STATE ENGINEER
NW 1/4 of NE 1/4 of Sect. 33, Twp. 10S
Rge. 43W, 6 P.M. OR

320
Total acreage irrigated and other rts.
ESTIMATED DATA OF WELL
Hole size: 30 in. to 250 ft.
 in. to ft.


Casing Plain 16 in. from 0 to 150 ft.
 in. from to ft.
Open or Perf. 16 in. from 15 to 250 ft.
 in. from to ft.

PUMP
DATA: Type Turbine HP 120 Size 16" Outlet

Use initiation date Aug 1 19 65.
(Use Supplemental pages for additional data)

Driller to furnish Log and History (Form E) within 30 days after completion of well.

Street Address or Lot & Block No.
Town or Subdivision



\$25.00 fee required for uses other than Domestic or Livestock.

THIS APPLICATION APPROVED
PERMIT NO. CP-10222
ISSUED: AUG 23 1965
DATE 19

Applicant Mrs. Britt Bell
Agent or Driller Scott D. Hargis Co. No. 457
Address Goodman, Kans

NOTE — SATISFACTORY COMPLETION REQUIRED FOR APPROVAL OF APPLICATION
No apparent interference RE

THE ABOVE APPLICATION, BEING A PART OF THIS PERMIT, IS APPROVED AS INDICATED.

Ralph Owens
ACTING STATE ENGINEER
Geo W. Colburn

SEAL

Rv

**OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES**

818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

1278

WELL PERMIT NUMBER 10222 -F R
DIV. 8 WD 49 DES. BASIN 1 MD 1

APPLICANT

BRITT BELL
215 CHERRY ST
BURLINGTON, CO 80807-

(719) 346-7264

APPROVED WELL LOCATION

KIT CARSON COUNTY
SW 1/4 SE 1/4 Section 28
Township 10 S Range 43 W Sixth P.M.

DISTANCES FROM SECTION LINES

30 Ft. from South Section Line
1940 Ft. from East Section Line

UTM COORDINATES

Northing: Easting:

PERMIT TO CONSTRUCT A WELL

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-90-111(1)(c) for the replacement of an existing well with permit no. 10222-F. The old well must be plugged in accordance with Rule 16 of the Water Well Construction Rules. The enclosed Well Abandonment Report form must be submitted within 60 days after the construction of the new well affirming that the old well was plugged.
- 4) This well must be constructed within 300 feet of the originally permitted location of the old well. The originally permitted location is described as a point 12 feet from the North section line and 2112 feet from the East section line of Section 33, Township 10 South, Range 43 West of the 6th P.M.
- 5) The maximum pumping rate of this well shall not exceed the claimed rate of 1000 GPM.
- 6) The annual withdrawal of ground water from this well shall not exceed the claimed amount of 400 acre-feet.
- 7) Approval of this replacement well permit shall not result in an expanded use of ground water. The use of ground water from this well is limited to the actual allowed timely beneficial use of the well. According to statements of the well owner, use of the well is limited to the irrigation of 160 acres in part of the E1/2 of Section 33, Township 10 South, Range 43 West of the 6th P.M.
- 8) Production is limited to the Ogallala aquifer. Plain casing must be installed, grouted and sealed to prevent diversion of water from other zones.
- 9) The owner shall mark the well in a conspicuous place with well permit number and name of aquifer as appropriate, and shall take necessary means and precautions to preserve these markings.

NOTE: The above uses are based on data in the permit file and are subject to verification by the Ground Water Commission and publication before issuance of a final permit.

APPROVED
RAC

State Engineer

DATE ISSUED

MAR 30 2001

By

EXPIRATION DATE

MAR 30 2002

Receipt No. 0454412A